THE PROGRAM

TOWERS PROJECT

THE NATIONAL
SHIPBUILDING
RESEARCH
PROGRAM

A PRIMITE PROMECT AND CHIEF THE PROMECT (ALL

AND TOWNSAM

Rectangular Vent Duct Standards

U.S. Department of Commerce
Maritime Administration

in cooperation with
Todd Shipyards Corporation

May 1977

UMTRI

48805

oversize NEMPOOGS

Transportation

Receptable lackly to

maintaining the data needed, and c including suggestions for reducing	lection of information is estimated to completing and reviewing the collect this burden, to Washington Headqu uld be aware that notwithstanding ar DMB control number.	ion of information. Send comments arters Services, Directorate for Info	regarding this burden estimate rmation Operations and Reports	or any other aspect of the 1215 Jefferson Davis	nis collection of information, Highway, Suite 1204, Arlington
1. REPORT DATE MAY 1977		2. REPORT TYPE N/A		3. DATES COVE	RED
4. TITLE AND SUBTITLE				5a. CONTRACT	NUMBER
Rectangular Vent	Duct Standards			5b. GRANT NUN	/IBER
				5c. PROGRAM E	LEMENT NUMBER
6. AUTHOR(S)				5d. PROJECT NU	JMBER
				5e. TASK NUMB	ER
				5f. WORK UNIT	NUMBER
Naval Surface War	ZATION NAME(S) AND AD rfare Center CD Co B 9500 MacArthur F	de 2230 - Design Int	0	8. PERFORMING REPORT NUMB	G ORGANIZATION ER
9. SPONSORING/MONITO	RING AGENCY NAME(S) A	AND ADDRESS(ES)		10. SPONSOR/M	ONITOR'S ACRONYM(S)
				11. SPONSOR/M NUMBER(S)	ONITOR'S REPORT
12. DISTRIBUTION/AVAIL Approved for publ	LABILITY STATEMENT ic release, distributi	on unlimited			
13. SUPPLEMENTARY NO	OTES				
14. ABSTRACT					
15. SUBJECT TERMS					
16. SECURITY CLASSIFIC	CATION OF:		17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON
a. REPORT unclassified	b. ABSTRACT unclassified	c. THIS PAGE unclassified	SAR	97	RESPONSIBLE PERSON

Report Documentation Page

Form Approved OMB No. 0704-0188

48805 oversize

FOREWORD

This is one of the many projects managed and cost shared by Todd Ship-yards Corporation as part of the National Shipbuilding Research Program. The Program is a cooperative effort between the Maritime Administration's Office of Advanced Ship Development and the U.S. shipbuilding industry. The objective, described by the Ship Production Committee of the Society of Naval Architects and Marine Engineers, emphasizes productivity.

The research effort was assigned by subcontract to John J. McMullen Associates, Inc. after evaluation of several proposals. Mr. Arthur L. Lewis was the Project Manager. He was assisted by Mr. J. C. Nilsen.

In behalf of Todd Shipyards Corporation, Seattle Div. R. F. Heady was the R&D Project Manager who provided technical direction, J. F. Curtis coordinated the final editing effort, and L. D. Chirillo was the R&D Program Manager having overall cognizance.

EXECUTIVE SUMMARY

When confronted with space limitations heat, ventilation and air conditioning (HVAC) designers must consider rectangular duct. Since size or component standards did not exist before now, such installations were mostly customized.

The standardization scheme contained herein establishes, in 2-inch increments. 106 different rectangular cross-sections which cover a useful range of applications. Further a reasonable, but reduced, number of fitting types are incorporated. These features were exploited to minimize the number of material items required and to simplify construction details.

Significant savings through use of these standards are predicted herein. But they impact on all shipbuilding disciplines in different degrees. Therefore any one functionary, e.g., a supervisory HVAC designer or a shop foreman, cannot be expected to assess the et impact of the standards on an entire shippard. Whether a shippard will benefit depends upon someone with an overview of all management functions requiring subordinates, representing direct and indirect cost areas, to make objective comments that can be assessed collectively.

Further, these standards are a first necessary step to apply computers for the detail design and fabrication of rectangular duct arrangements as is now being done for piping systems.

Every shipbuilder should read at least the first 6 pages. The remainder is detailed and contains comprehensive cost comparisons. It should be analyzed by experts in estimating, planning (including design and material procurement), production and performance measurement.

TABLE OF CONTENTS

LIST OF FIGURES

LIST OF TABLES

1.0 INTRODUCTION

- 1.1 General
- 1.2 Approach
- 1.3 Findings

2.0 DESCRIPTION OF THE STANDARDS

- 2.1 General
- 2.2 Summary of Elements Standardized

3.0 IMPACT OF THE STANDARDS

- 3.1 In Overall Management
- 3.2 In Planning
 - 3.2.1 Design
 - 3.2.2 Material Procurement
 - 3.2.3 Resource Allocation
- 3.3 In Production

4.0 RATIONALE FOR SPECIFIC IMPROVEMENTS

- 4.1 Sizes
- 4.2 Sheet Material
- 4.3 Seams
- 4.4 Transverse Connections
 - 4.4.1 Flanged
 - 4.4.2 Non-Flanged
- 4.5 Transformations
- 4.6 Access Plates
 - 4.6.1 Quick-Acting
 - 4.6.2 Bolted
- 4.7 Belimouth Terminals
- 4.8 Wire Mesh Screening

5.0 IMPACT OF PRESSURE DROP LOSSES

6.0 PROBLEM OF DISPROPORTIONAL SPLITS

APPENDIX A - DESIGNER'S PAMPHLET

APPENDIX B - SAMPLE CONSTRUCTION DRAWINGS

APPENDIX C - SAMPLE TABLES FOR MATERIAL QUANTITIES AND DIMENSIONS

APPENDIX D - RESEARCHER'S UNDERSTANDING OF SHIPBUILDING FUNCTIONS

APPENDIX E - AREAS FOR FUTURE STUDY

APPENDIX F - DUCT SIZE UTILIZATION: FIRST GENERATION OF SPLITS

APPENDIX G - COST ANALYSES

APPENDIX H - SPECIFICATION TO INVOKE RECTANGULAR VENT DUCT STANDARDS

APPENDIX I - SURVEY OF FABRICATORS .

LIST OF FIGURES

- 2-1 Rectangular Duct Standards Key Plan
- 3-1 Management Cycle
- 4-1 Radius Corner Availability
- 4-2 Quick-Acting Access Plates
- 4-3 Bellmouth Terminal
- 5-1 System Schematic

LIST OF TABLES

- 4-1 Sheet Material Utilization
- 4-2 Standard Method for Determining Bellmouth Radius
- 4-3 Current Method for Determining Bellmouth Radius
- 5-1 Comparison of Total Pressure Drop Losses to Terminal Points

1.0 INTRODUCTION

1.1 General

One reason for using standards is to better define ships' components so that risks and costs are minimized for shipbuilders and their material suppliers as well as for owners and underwriters. Standards achieve this by eliminating generalities and thus provide a basis for common understanding. But, heretofore none have been developed for rectangular vent duct. Thus the objectives of this project were to:

- e develop standard sizes and components for rectangular vent duct, and to
- identify potential cost savings from such standardization.

The results include, in addition to this report, a designer's pamphlet, matching construction drawings, and a computer prepared tabulation of dimensions and quantities of required materials. Thus everything necessary for designers, plunners, buyers, and craftsmen to support and utilize the standards has been developed.

The purpose of this report is to notify shipbuilders of the available standards for rectangular vent duct and to present pertinent discussions and cost analyses which will facilitate implementation.

In order to produce the standards, the researcher:

- reviewed several shipsets of different ventilation systems drawings.
- · searched and reviewed the literature.
- solicited and analyzed information from many vendors.
- explored the duct components used in both U.S. and foreign shoreside industries for possible adaptation in ships,
- inspected several U.S. and foreign ships to determine current practices.
- reviewed regulatory constraints and MarAd and Navy specifications.
- discussed the standardization scheme with people in the U.S. Coast Guard (MMT) and with the Public Health Service in Washington, D.C., and
- acquired an understanding of current practice in direct meetings with design and production people in seven major U.S. shipbuilding yards.


1.3 Findings

Overall costs for rectangular vent duct installations in ships could be reduced significantly through the use of standards. For example a 20% savings is estimated for such installations in a 75,000 DWT Panamax tanker. The savings are manifest in all of the required shipbuilding disciplines and mostly result from eliminating virtually all custom components and thus allowing a reduced number of line items² both for purchased and in-process materials.

^{1.2} Approach

^{&#}x27;A specification to invoke these standards is in Appendix H.

²unique items which must be separately identified in drawing material lists, purchase requisitions, purchase orders, warehousing, and in work orders.



2.0 DESCRIPTION OF THE STANDARDS

2.1 General

The components for which standards were developed are illustrated in Figure 2-1. Specifics of the standardization scheme are described in the Designer's Pamphlet which is reproduced in its entirety in Appendix A. This pamphlet is a catalog of standard components that is intended for HVAC' designers. Although complete sets of matching construction drawings and computer prepared tabulations of dimensions and quantities of required materials are available; only typical pages are incorporated in Appendices B and C respectively. Regarding the construction drawings, each is complete to facilitate fabrication. They even include developed views for the layout of patterns.

As required by the research specification the standards:

- provide for normal velocities up to 4000 feet per minute, and
- cover a full range of duct sizes.
- Also, the researcher was able to incorporate some simplified construction details as compared to current practice. But, for certain elements such as basic materials and fire dampers no improvements were found.

2.2 Summary of Elements Standardized

Element	Sta nd ardization
Element	Standaraization
sizes	depth and width by two-inch increments resulting in 106 different cross sections from 2" x 4" through 24" x 24" to 18" x 54"; radius corners in only three radii for most strength penetrations.
materials	steel in five thicknesses: 20. 16 and 11 gauge and 3/16 and 1/4 inch.
duct reinforcement	applicability and spacing
cibows	four types: full throat, half and quarter throat with and without splitters, and vaned turn
offsets	two types: full and half-throat radii
transformations	three symmetrical and three flat-sided: rectangular-to-rectangular, rectangular-to-radius corner, and rectangular-to-round
branch take-offs	ten types: variations of rectangular and round, normal and flared, 90° and 45°, from straight and transforming mains
terminals	cone and bellmouth; radius selection for the bellmouth reduced to seven dimensions
transverse connections	seven flanged types and five non-flanged; bolt hole spacing standardized; structural 'pop' rivets on 2-inch centers with no sculant required
access covers	dimensions and details
wire mesh screening	dimensions and details
tensile fasteners	22 line items

^{&#}x27;Heating, Ventilation and Air conditioning.

²to U.S. shipbuilders from R&D Program Menager, Todd Shipyards Corporation, Seattle Division, P.O. Box 3806, Seattle, WA 98124; otherwise when cataloged, from the National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161.

3.0 IMPACT OF THE STANDARDS

3.1 In Overall Management

The research specification required that all comment be in the context of conventional shipbuilding functions. Thus the researcher's understanding of these functions and how they interact are pertinent and are included in Appendix D.! But assessing the full impact requires appreciation of the entire management cycle, see Figure 3-1, because every management function benefits from the use of standards.

No matter to what degree the functions and information flows illustrated in Figure 3-1 are formalized, or even if they are not at all formalized, they must exist everywhere ships are built for profit. Decisions made in forecasting, planning, scheduling and production are controlled by information both from previous steps and from feedback obtained from subsequent steps. Standards provide the necessary common understanding which is just as critical between shippured functionaries as it is between shipbuilders and owners. Thus, the reitangular vent duct standards will benefit estimators, schedulers and accountants by providing simplified quality information that facilitates prediction, implementation and evaluation. But, there is much greater potential benefit in planning and production.

3.2 In Planning

As used herein planning includes design of ventilation system arrangements, material procurement and resource allocations because they are interdependent.

3.2.1 Design

Standards will lead designers away from unproductive fine-tuning of HVAC systems and reduce the number of time consuming design iterations. The fact is that many HVAC systems are built to design constraints which far exceed the accuracy of the basic flow factors. There are surprisingly wide gaps in the experimentally verified data on system losses. For example, almost no test data exists for return-side takeoff losses. Also, popular rules-of-thumb introduce considerable inaccuracy in bringing loss factors from test points to design conditions. Two-inch increments and

the elimination of complicated components will force a reduction in the costly, spurious accuracy common in current designs. Allowances for such accuracy in a custom designed system and the need to select "the next largest" from a limited number of available fan sizes often combine to produce excessive air flow. When the flow is necessarily reduced with a damper, frequently the system becomes no more efficient than it would be if arranged with standard components that facilitate productivity.




Figure 3-1 Management Cycle

^{&#}x27;The application of this understanding to a typical ventilation system is also included.

^{*}This is discussed in Appendix E which identifies areas for future study.

³By strict application of the common rule-of-thumb, a 16° miter would have five times the loss of a 10° efbow - impossible!

The responsibility for much of ventilation systems' construction costs rests with HVAC designers. Sometimes a situation occurs where an extra hour or two over the budget allocated for designing certain features, can save a week's work in production. But the immediate design supervision is rarely in a position to authorize extra time. Thus frequently the opportunity for cost reduction is rationalized away. This problem is greater when the design is developed away from the shippard. Close linison is required between designers and fabricators for ideal cost returns. The designer's pamphlet and the matching construction drawings produced by the researcher reflect such liaison and can have continuing impact on construction costs. They already incorporate economic features suggested by shop people and they can serve as a common basis for communication to add even more productive features.

Further, preparation of the rectangular vent duct standards is a significant completed effort that is prerequisite for inputting the configurations and dimensions of each component into a computer. Thus it is now practical to regard a rectangular vent duct system as just another "piping" system and to "... provide pictorial output from computers through devices such as cathode ray tubes and numerically controlled plotters. Such systems have a high potential for bringing about significant reductions in the cost of plan production which represents about 2/3 of the total cost of a post contract design effort." For achieving full benefit, consideration must be given to the recommendations contained in Appendix E for developing applicable computer programs.

3.2.2 Material Procurement

The standards feature minimization of the number of separate material line items required. For example, sheet steel is limited to only five thicknesses. This reduction in the number of different material items can save an estimated 15 to 20 percent in costs associated with purchasing, storage, retrieval and in-process control. Additional savings may come from the increase in size of bulk orders.

And, for some yards the standards permit a wider range of make-or-buy alternatives. They increase the probability that prefabricated components, and even subassemblies, will be bought from a subcontractor because the standards contribute significantly to assurances for correct dimensions and quality regardless of the point of manufacture.

'from a preliminary draft of the report "Improved Design Process" D. C. MacMillan for the National Shipbuilding Research Program. 31 January 1977, p. 3-46. Because of the standards' simplicity all required material identities and quantities were easily tabulated by computer. Thus, experienced designers do not have to be concerned with preparation of material lists for standard components. The tabulation can be used by less experienced people using manual procedures. Elsewhere, shipyards can use the available programs for inputting the required indentities and quantities into their own computers for preparation of material lists, requisitions, etc.

3.2.3 Resource Allocation

This function is made easier by the use of standards because the process of allocating manhours, materials, facilities and time has to be done only once for a particular component. Thereafter the same information can be used repeatedly.

in addition, the use of standard components increases the opportunities to elect cost saving alternatives, e.g., the ready detection of identical components and subassemblies which should be batch manufactured and of those items which should be subjected to make-or-buy analyses.³

Applying computers to all resource allocation tasks are greatly facilitated through use of the standards.

3.3 In Production

The standardization of sizes and fittings such as elbows and transformations produce cost savings because they eliminate most of the need for special cases. Thus expenditures of shop resources will be reduced for developing, storing and retrieving patterns. Further benefit accrues from having to contend with fewer material items in shops' stores. In addition, the standardization makes it practical to use the same construction drawings in ships of various sizes and types.

The construction drawings produced by the researcher anticipate all information needed by craftsmen. Preparation of end connections, notching, allowances for longitudinal and transverse seams, etc., are detailed. Pattern configuration and layout possibilities are noted along with required dimensions. This information is sufficiently detailed to facilitate digitizing developed views and automatic cutting.

²to U.S. shiphuilders from the R&D Program Manager. Todd Shipyards Corporation. Seattle Division. P. O. Box 3006. Seattle. WA 90124 and when cutaloged from the National Technical Information Service. 5285 Port Royal Road. VA 22161.

See Appendix I for a listing of potential vent duct manufacturers.

4.0 RATIONALE FOR SPECIFIC IMPROVEMENTS

4.1 Sizes


106 standard sizes were developed in 2-inch increments in both width and depth. They are given in the Designer's Pamphlet, Appendix A. Except for two cases, the sizes do not go beyond a 1 to 3 aspect ratio because higher ratios may reduce geometric integrity and increase the chance of duct "panting." The 2-inch depth sizes have a 1 to 4 limiting ratio and the 4-inch depth sizes have a 1 to 3.5; both are acceptable because of structural support from the corners. Although not used in quantity, ducts above 12-inches in depth with aspect ratios exceeding 1 to 2.5 have been included. They are frequently used in machinery spaces for the larger branches required between the main vertical trunks and the smaller distributive branches.

The number of sizes is determined in large part by the need for reasonable efficiency in splitting to standard sizes. Section 6 discusses the effects of disproportional splitting forced by the 2-inch increments in duct size. Appendix F shows the split availability for each depth and gives the duct size utilization for the first generation of splits. Utilization of standard sizes is efficient up to the 12-inch x 36-inch size; this range accommodates a large percentage of normal applications.

Ducts larger than the standard sizes are in most instances either built into the ship or have their shape determined by structure, adjacent builtheads, space arrangements, etc. These should remain special cases.

The impact of size standardization is pervasive. Most important, it is a prerequisite for much of the simplification of components that has been accomplished. It allows component energy losses, material requirements and fabrication dimensions to be tabulated. It increases the number of like parts, decreases the likelihood of peculiar duct components, and therefore increases the possibilities for manufacturing economies in the sheet metal shop.

Figure 4-1 presents the standard and acceptable alternative radius corners for each duct depth. The standard radii will suit structural requirements for almost all strength penetrations. Cost savings may come directly from the fact that only three templates are required for the full range of sizes. Savings are assured where the use of the standard radii allows the use of an abrupt transition in lieu of a transformation. The standard radii are also prerequisite for the standardization of flanges and bolt hole spacing.



SMALL CROSS-SECTIONAL DIMENSION OF COAMING	AVAILABLE RADIUS CORNERS (INCHES)								
D OR W	STANDARD	ONLY AS NECESSARY							
(INCHES)	R1	R2	R3	R4					
2	1		_						
4	1	2	_	_					
6	1	3	-	-					
8 ·	1	2	4	_					
10	2	3	5						
12	2	4	6	-					
14	2	4	7	-					
16	2	4	6	8					
18	3	5	7	9					
20	3	5	7	10					
22	3	6	8	11					
24	3	6	9	12					

Figure 4-1 Radius Corner Availability

4.2 Sheet Material

Sheet steel, either galvanized or otherwise protected, is the only material specified. Material thickness has changed only in the lighter gauge duct, 24 to 16 gauge; two gauges replace five.

The reduction in line items was made after careful study of each of the following:

- current naval and commercial marine design.
- current commercial design shoreside.
- · capabilities of seaming machines.
- · desire to minimize stock inventories,
- need to meet regulatory body requirements.
- · demands made on materials in the shipboard environment, and
- need to meet duct stiffness criteria.

While accommodating all of these considerations, the standards call for only two gauges, 20 and 16 gauge, for materials less than 1/8-inch thick. This eliminates the use of 18, 22 and 24 gauge material. The elimination of 24 gauge will not significantly affect costs because this gauge is currently used only in duct where the largest cross-sectional dimension is less than 6 inches. Moreover, 24 gauge is not suitable for applications requiring B Class fire protection. Dividing the existing 18 gauge applications between 20 gauge and 16 gauge is an even cost trade. Similarly, the elimination of 22 gauge material is roughly an even trade because the heavier 20 gauge is both better suited to welding and less likely to be damaged in storage. Characteristics and applicability of the sheet material are shown in Table 4-1.

	COMPONENT SIZE (INCHES) (1)	GAUGE (2)	THICKNESS (INCHES) (2)	WEIGHT (LBS/FT²) (3)	COST (\$/FT ²) (4)
	ALL COMPONENTS MEANT TO BE WATERTIGHT, OR EXPOSED TO WEATHER	11	.1233	5.0357	1.00
	ALL VERTICAL COMPONENTS SUBJECT TO DAMAGE (OUTSIDE OF DRY CARGO HOLDS)	11	.1233	5.0357	1.00
	ALL COMPONENTS DESIGNED TO SATISFY "A" CLASS FIRE PROTECTION REQUIREMENTS	11	.1233	5.0357	1.00
	ALL HORIZONTAL COMPONENTS IN DRY CARGO HOLDS	– .	.1875	7.65	1.53
	ALL VERTICAL COMPONENTS IN DRY CARGO HOLDS	_	.250	10.2	2.04
-	ALL OTHER VERTICAL EXPOSED COMPONENTS	16	.0635	2.5958	.50
	ALL OTHER HORIZONTAL OR CONCEALED VERTICAL COMPONENTS WHOSE SIZE IS:		:	:,	
	LESS THAN 6	20	.0396	1.6207	.30
	6 - 12	20	.0396	1.6207	.30
	1212 - 18	20	.0396	1.6207	.30
	181/2 - 24	20	.0396	1.6207	.30
	24% - 30	16	.0695	2.5958	.50
	OVER 30	18	.0635	2.5958	.50


LARGEST CROSS - SECTIONAL DIMENSION.
 MANUFACTURERS STANDARD GAUGE. THICKNESS INCLUDES GALVANIZING FOR MATERIALS LESS THAN 3/16".
 BASIC WEIGHT PLUS GALVANIZING FOR 11 GAUGE AND THINNER. BASIC WEIGHT ONLY FOR 316" AND 14" THICK MATERIALS.
 COST DATA IS FOR FEBRUARY 1978.

Table 4-1 Sheet Material Utilization

4.3 Seams ·

Longitudinal seams have been included in the scheme more because of their effect on transverse connections and components than because of any improvement in fabrication methods. All seven types mesh smoothly with the rest of the standards. The only significant change from current practice is the use of structural 'pop' rivets on 2-inch centers with no sealant for the Type 4 riveted seam described in the following:

TYPE 1 is the standard Pittsburgh corner lock commonly used by ship-yards for the corner longitudinal seams on rectangular straight duct, elbows, and non-radius corner transformation pieces. It is a strong seam usually formed by machines specifically dedicated to it, and set by hand. The seam does pose problems to transverse connection methods.




TYPE 2 is a welded corner seam now in use by some shippards. It is recommended where the necessary welding skills and equipment make it economically competitive. Its use can simplify transverse connections. The only change recommended would be to bend one edge to prevent welding burn-through and to aid in duct alignment. This bend isn't necessary if the yard's light-gauge welding is highly developed.

TYPE 3 is one of two types of longitudinal seams used where corner seams are not possible. This seam is seldom used in material heavier than 20 gauge. Maintaining duct size tolerance is more difficult than with other seams, and there is little play for duct alignment and adjustment.



TYPE 4 is the button punch snap lock corner seam which is coming into prominent use in the commercial shoreside industry. It is formed by machines designed for the purpose. Although possible, use of this seam on elbow corners is not recommended because of the problems involved in bending the seam without

affecting the locking feature. This type is, however, recommended for straight duct and non-radius corner transformation pieces in the 20 gauge material range. The lock is accomplished by pushing the two pieces together; setting or peening over by hand is not required. Cost is roughly the same as the Pittsburgh corner lock in the 20 gauge range.



TYPE 5 is a lapped riveted or spot welded seam. It is one of the two types of longitudinal seams commonly used by shipyards where corner seaming is not possible. Its main application is on transformation pieces with radius corners. The 'pop' rivets currently used have been replaced by structural 'pop' rivets, and the rivet spacing has been changed from 1½-inches C-C to 2-inches C-C. Sealing of the rivets should be more than offset by the savings from increased spacing and elimination of sealing.²

TYPE 6 is similar to Type 3 except that the materials involved are thicker, and therefore, no bend is required to prevent welding burn-through.³

TYPE 7 is a butt-welded, water tight seam for thicker gauge materials only. Type 6 or Type 7 seams may be used interchangeably at the discretion of the fabrication shop.²

^{&#}x27;See Appendix A. Sheet 16, for illustration of Type 2.

^{*}See Appendix A, Sheet 16, for illustrations of Types 5, 6 and 7.

4.4 Transverse Connections

4.4.1 Flunged

The standardization scheme incorporates a number of small changes to existing flange details which should save 20 or 30 percent per assembly. The savings are difficult to estimate. Some are simplified shippard fabrication, reduced inventory control, the option of buying from outside sources, and the use of the same construction drawings for all ships.

Savings appear certain from the change to standard bolt hole spacing. This allows use of fewer templates. Only twelve are required for all possible radius corners for the standard sizes. Because many of the possible radii will seldom be needed, only three or four templates will be in constant use. Bolt hole standardization eliminates the need to fabricate flungers as mated pairs that must be kept together. The standards permit any two flunges of a given duct size and corner configuration to be mated, even if one is installed upside down. This encourages bulk purchases of flunges from outside sources. Savings also result from the following:

- Bolt hole size is independent of the mating flange type.
- Hex washer head boits and flange nuts have been selected and sized to eliminate the need for washers and to allow a reasonable amount of bolt hole mismatch. (These can be bought with bearing surfaces which act as lock washers offering a more secure connection.)
- Smaller diameter fusteners are specified to further reduce costs. For example 1/4-inch bolts are substituted for the 3/8-inch presently used to connect non-watertight duct to coamings.
- Three basic types of flanges and material configurations have been reduced to two.
- For several flange types, 1/8-inch thick material is used when attached to 1/8-inch components, in place of the 3/16-inch thick material now used.
- Rivet spucing has been revised upward to 2-inch C-C from 1½-inch C-C.
 For this spacing structural break-mandrel type rivets must be substituted for the current non-structural type. The better rivet eliminates the widespread problem of having mandrels fall out after fabrication. Also, the practice of sealing the rivet heads is no longer required.

4.4.2 Non-flanged

More important than flange details is the scheme's emphasis on non-flange connections. Appendix G includes a cost comparison between a flange and recommended non-flange connections. Savings may be over 50 percent in substituting non-flange for flanged.

4.5 Transformations

The Designer's Pamphlet recommends that abrupt transformations be used wherever feasible, e.g., a standard Type 2 flange can usually serve as the 'transform piece' to a radius corner coaming. The higher losses are offset by savings in fabrication costs. If the abrupt transform proves inadequate, the standards offer two gradual transforms.\(^1\) Estimated fabrication times are in Appendix G. The designer's second choice is an equal area, rectangular-to-rectangular transform costing approximately 2.25 fabrication hours. The standard Type 2 flange again makes the transition to the radius corner coaming. The worst alternative is the rectangular-to-radius corner transform with an estimated cost of 3.75 fabrication hours.

To facilitate more frequent use of abrupt transforms, the standards hold coaming radii to the minimums which meet the strength requirements for bulkhead penetrations. Analysis showed that for commercial ships larger radii would be necessary only in very peculiar circumstances and would likely cost the shipyard two expensive transforms.

4.6 Access Plates


4.6.1 Quick-acting

Access plates now in general use are variations of a round type, fitted with wing nuts, as shown in Figure 4-2. However, the flat-oval type, also shown in Figure 4-2, is more productive because duct preparation is limited to cutting a simple access hole; no welding is involved. Further, required material line items are reduced from five to one. This flat-oval cover is a Navy standard that has already been used in some commercial ships. See Appendix G for cost information.

4.6.2 Bolted

No changes are proposed to the bolted access plates now in use except to offer alternative fasteners. The alternative fasteners are much less expensive (see the cost comparison, Appendix G), but not all shipyards have the presses required to seat them. Therefore their use has not been considered for estimating the cost savings available through the use of standards.

^{*}For completeness, the standards also include a rectangular-to-round transformation and flat-sided versions of the three basic types.






Figure 4-2 Quick-Acting Access Plates


4.7 Bellmouth Terminals


Belimouth terminal design has been simplified; only seven curved templates will be required to produce the end details for all belimouths. Referencing the developed view, Figure 4-3, the radius R is determined as shown in Table 4-2.

Cost analysis is difficult, because the fabrication procedure will remain about the same. However the increased use of templates for the end curve, allowed by the standardization, will eliminate the special curve developments presently required. A further benefit will result from the standardization of wire mesh screening which the standard belimouth terminal permits. The detailed cost comparison, Appendix G, predicts a savings of 15 to 20 percent per belimouth: 0.5 hours fabrication time (less 25¢ for additional material) due to reduced layout time.

4.8 Wire Mesh Screening

All rectangular openings have been standardized for which wire mesh screening may be required. These openings include open-end duct, cone terminals, belimouths, side of duct openings, and weather openings. The dimensions of all openings and all required wire mesh screens are based on 1-inch increments. Except for weather openings, the details of the wire mesh housing, bolted locations, and corresponding screen configuration will not vary with the type of opening. No cost analysis was attempted for these improvements. But, savings are expected from the elimination of the many small changes associated with the current methods of sizing openings and from the simplification of such items as 'U' frames, retaining frames and fastening hardware.





Tuble 4-2 DETERMINING BELLMOUTH RADIUS R

X (larger of D or W)	R
2" < X < 8"	l"
8" < X ≤ 16"	2"
16" < X ≤ 24"	3"
24" < X ≤ 32"	4"
32" < X ≤ 40"	5"
40" < X ≤ 48".	6"
48" < X ≤ 54"	7"

In no case is the standards' R more than 7/8 inch different from R calculated by current methods shown in Table 4-3. The Energy Loss Factor is the same for both standard and current practice, i.e., 0.15 hv (velocity head) for all values of

Table 4-3 CURRENT METHODS FOR DETERMINING RADIUS R

Method A:	X (larger of D or W)	<u>R</u>		1 7
	X < 8" X > 8"	l" .125X	Y 1	(Runge of R is from 1" to 6.75")

Method B:
$$\frac{Y \text{ (smaller of D or W)}}{\text{for all Y}}$$
 .6Y

(Range of R is from 1.2" to 14.4"; limited to 9.75" max. by some design shops.)

These current methods produce from 14 to 47 different values for R over the range of the standard sizes. By the most widely used method (Method A), R increases in 1/8-inch increments for every 1 inch increase in the maximum duct dimension.

5.0 IMPACT ON PRESSURE DROP LOSSES

To determine the impact of the standards on duct pressure drop losses, a typical system was selected from one of the vessels reviewed during the first phase of this project. The system was labeled SSI (supply system) and is shown schematically in Figure 5-1. The entire system (except for one branch for which data was not available) was calculated exactly as depicted on the vent arrangement plans. The same system was then recalculated as SSI' with the following changes:

- All duct sizes were made standard except those connecting to equipment.
- All elbows were made standard and those less than 15° angle of turn were eliminated and calculated as mitres.
- All transformation pieces between ducts and radius corner spools were eliminated, and losses for abrupt changes were calculated.
- All splits were made of standard sizes, and where this violated the proportional split concept, these were calculated to show the resulting abrupt losses.

All of the changes were investigated with respect to feasibility on the vent arrangement plans.

Table 5-1 is the tabulated comparison of pressure drop losses to each terminal point. The differences in pressure drop losses - column \(\triangle P\) - shows that design to the standards had no significant impact on the efficiency of the system. Moreover, finer points such as the elimination of all transformation pieces between rectangular duct and radius corner spools were separately evaluated and shown to have little impact. The small differences in losses for the study system indicate that the design of rectangular HVAC systems to the standards is unquestionably practical.




Figure 5-1

TABLE 5-1
SSI and SSI' - COMPARISON OF TOTAL PRESSURE DROP LOSSES TO TERMINAL POINTS

Terminal Point No.	Current Practice: SS1 (See Note I)	Standards Applied: SS1' (See Note 2)	ΔP = SSI-SSI
3	1.892	1.927	035
6	1.981	1.959	.022
8	1.882	1.874	.008
10	2.116	2.108	.008
12	2.152	2.144	.008
13	2.195	2.187	.008
15	1.219	1.307	088
20	2.200	2.228	028
21	2.175	2.203	028
22	2.159	2.169	010
23	NO INFORMAT	TION AVAILABLE FO	R THIS TERMINAL
25	2.293	2.286	.007
27	2.233	2.226	.007
28	2.190	2.183	.007

- NOTE 1 Pressure drop losses as calculated for SS1 from the vent drawing with no changes.
- NOTE 2 Pressure drop losses as calculated for SS i' from the vent drawing with the following changes:
 - a) All duct sizes made standard except for those connecting to equipment.
 - All elbows made standard, and those less than 15° turn eliminated and calculated as mitres.
 - All transformation pieces between ducts and radius corner spools eliminated and losses for abrupt changes calculated.
 - d) Abrupt losses calculated at splits where the use of standard sizes violated the proportional split concept.
- NOTE 3 Calculations were made from Navy Duct Size Factor Wheel and ASHRAE Handbook of Fundamentals 1972.

6.0 PROBLEM OF DISPROPORTIONAL SPILITS

One of the main problems associated with the standardization of rectangular duct sizes is that as the number of specific sizes is reduced, the probability of disproportional splits becomes larger. This problem is really two-fold: not only do abrupt velocity changes cause dynamic energy losses, but also the uncertainty of the resulting steady state conditions becomes greater as the proportionality becomes less. The cost of additional fan energy can of course be subtracted from the savings in construction cost to get the estimated net savings. The uncertainty of resulting steady state air flow conditions, however, is not easily predetermined and can cause major difficulties during the system balance tests.

The worst effect of disproportional splitting occurs in the case of a small duct carrying air at high velocities. The worst case within the range of the proposed standard sizes and at the highest design velocity is as follows: assuming that a one inch split was previously the desired minimum and that a 4-inch x 4-inch duct carrying 444 cfm at 4000 fpm is to be divided into two ducts, a 1-inch split would divert 111 cfm proportionately. The resulting two ducts would then be 1-inch x 4-inch duct carrying 111 cfm at 4000 fpm and a 3-inch x 4-inch duct carrying 333 cfm at 4000 fpm.

Assuming that the split is made on the supply side of a system, the conditions that a 2-inch incremental splitting standard would create would be: an abrupt expansion of the 111 cfm to 2000 fpm, resulting in a dynamic loss of .25-inch H₂0; and an abrupt contraction of the 333 cfm to 6000 fpm, resulting in a dynamic loss of .28-inch H₂0. In this worst case, the resulting losses are obviously unacceptable. However, this case is not likely on the exhaust side of a system, because if standard sizes were used, their combination would presumably be another standard size.

The best case resulting from the disproportional division of a main duct carrying air at 4000 fpm would be where a 54-inch x 18-inch duct were divided into a 26-inch x 18-inch duct when an equal split is required. The resulting abrupt expansion loss would be .002-inch H_10 , and the abrupt contraction loss would be .009-inch H_20 . Just as obviously, these losses are acceptable.

The above cases have been calculated assuming the highest velocity and greatest disproportionality and so reflect the greatest losses for both the worst and best cases. Most actual losses will be between the values calculated and lower than the arithmetic mean. It is estimated, therefore, that in the majority of cases the losses will be acceptable.

APPENDIX A

DESIGNER'S PAMPHLET

This appendix contains a catalog to facilitate a designer's selection of standard components. It must be used with the available dimensional criteria and material requirements; see Appendix C.

Any proposals for significant modification of this Appendix, or of Appendix C. should be addressed to the: R&D Program Manager. Todd Shipyards Corporation. Seattle Division. P. O. Box 3806. Seattle, WA 98124.

	INDEX		REV	ISIONS			
SHEET NO.	CONTENTS	REV	DESC	RIPTION		DATE	VPV [
1	TITLE SHEET, REVISIONS, AND INDEX.						
2-3	index (contd), references, and approvals.]				1 1	
4-12	NOTES.]				1 1	
13-14	STANDARD SIZES, MATL REQT, AND WEIGHTS.]			,		
15	radius corner selection, and cross-sectional]				1 .1	
	areas.]					
· 16	STRAIGHT DUCT.]				1 1	
	TYPES GAND 7 LONGITUDINAL SEAMS (WATERTIGHT).]		•			
	TYPES I TO S LONGITUDINAL SEAMS (NON-WATERTIGHT).]			_	1 1	
17	TYPE I ELBOW (FULL-THROAT RADIUS).]}			·	1 1	
	type 2 elbow (half-throat radius).] '				1 1	
	TYPE ? ELBOW (QUARTER-THROAT RADIUS).]					
. 18 .	TYPE 4 ELBOW (VANED).]					
	TYPE I OFFSET (FULL-THROAT RADII).	1					
	TYPE 2 OFFSET (HALF-THROAT RADII).]]					
19	TYPE I TRANSFORMATION (SYMMETRICAL).	11					
	TYPE 2 TRANSFORMATION (SYMMETRICAL).]] .					
	TYPE 3 TRUSFORMATION (SYMMETRICAL).]		•			
20	TYPE 4 TPANSFORWATION (FLAT-SIDED).]}					
	TYPE 5 TRANSFORMATION (FLAT-SIDED).						
	type g transformation (flat-sided).						
21	TYPE I BRANCH TAKE-OFF (RECT BYANCH, CONSTANT	1					
	MAIN SIZE, 90°).						
	TYPE 2 BRANCH TAKE-OFF (ROUND BRANCH, CONSTANT			DESIGNE	RS PAME	דם ונג	
	MAIN SIZE, 90°).				SUILDING RESEAR		
	TYPE 3 BRANCH TAKE-OFF (FLARED RECT BRANCH,						
	Constant Main Size, 90°).			RECTANG	ULAR DUCT STA	ND AR DS	•
22	TYPE 4 BRANCH TAKE-OFF (FLARED ROUND BRANCH,]]		5128 MARAD CON1	1000 MAWING	No.	100
•	CONSTANT MAIN SIZE, 90°).			B 2-36233	4966-SK	-006	T
	CONTINUED ON SH 2.		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	SEALS NONE		1 11 2 1 07	4

	INDEX (CONTD)		REFERENCES	
SHEET NO.	CONTENTS	NO		IDENTIFICATION
22	TYPE 5 BRANCH TAKE-OFF (RECT BRANCH, CONSTANT	1	BOOKLET PLAN (COMPUTER OUTPUT)-	TODD DWG NO.
	MAIN SIZE, 45°).		"DIMENSIONAL CRITERIA AND MATERIAL	
	TYPE G BRANCH TAKE OFF (ROUND BRANCH, CONSTANT		QUANTITIES IN SUPPORT OF RECT	
	MAIN SIZE, 45°).		DUCT STANDARDS, CONSTRUCTION	
23	TYPE 7 BRANCH TAKE-OFF (RECT BRANCH,		AND FABRICATION."	•
	TRANSFORMING MAIN, 90°).	2	MILITARY STANDARD-'ABBREVIATIONS	MIL-STD-12C
	TYPE B BRANCH TAKE-OFF (ROUND BRANCH,		for use on drawings,	
	transforming main, 90°).		SPECIFICATIONS, STANDARDS AND	
	TYPE 9 BRANCH TAKE-OFF (RECT BRANCH,		TECHNICAL DOCUMENTS."	
	TRANSFORMING MAIN, 45°).	3	"RECTANGULAR DUCT STANDARDS -	TODO DWG NO.
24	TYPE IO BRANCH TAKE-OFF (ROUND BRANCH,		CONSTRUCTION AND FABRICATION "-	
	TRANSFORMING MAIN, 45°).		NATIONAL SHIPBUILDING RESEARCH	
	TYPE I TERMINAL (CONE).		PROGRAM.	•
	TYPE 2 TERMINAL (BELLMOUTH).	4	UNITED STATES COAST GUARD-RILES	
25	TYPE I TRANSVERSE CONN (FLANGED, WATERTIGHT).		AND REGULATIONS (AS APPLICABLE TO	
	TYPE 2 TRANSVERSE COMM (FLANGED, WATERTIGHT).		class a & B fire protection).	:
	TYPE 3 TRANSVERSE CONN (FLANGED, WATERTIGHT).	5.	UNITED STATES PUBLIC HEALTH	
26	TYPE 4 TRANSVERSE CONN (FLANGED, NON-WATERTIGHT).		SERVICE PUBLICATION NO. 393 -	1
- 1 ·	TYPE 5 TRANSVERSE CONN (FLANGED, NON-WATERTIGHT).		"HANDBOOK ON SANITATION OF	······································
	TYPE G TRANSVERSE CONN (FLANGED, NON-WATERTIGHT).		VESSEL CONSTRUCTION"(AS APPLICABLE	
27	TYPE 7 TRANSVERSE CONN (FLANGED, NON-WATERTIGHT).		TO RATPROOFING).	
T	TYPE B TRANSVERSE CONN (NON-FLANGED, WELDED,			
	WATERTIGHT).			•
	TYPE 9 TRANSYERSE CONN(NON-FLANGED, RIVETED,	ŀ		
	NON-WATERTIGHT).			
28	TYPE IO TRANSVERSE CONN (NON-FLANGED, DRIVE-SLIP,		NATIONAL SHIPBUILDIN	G RESEARCH PROGRAM
	NON-WATERTIGHT).		RECTANGULAR D	UCT STANDARDS
	TYPE II TRANSVERSE CONN (NON-FLANGED, 5-CLIP/		5126 MASAS CON12 1000	DR AWING NO. 14
	DRIVE-SLIP, NON-WATERTIGHT).			
	CONTINUED ON SH 3.		I I I I I I I I I I I I I I I I I I I	1966-5K-006

INDEX (CONTD) APPROVAL DATE SHEET NO. CONTENTS USCG TYPE 12 (BASIC) TRANSVERSE CONN (NON-FLANGED; ABS LATCH TYPE, NON-WATERTIGHT). PHS TYPE 12 (ALTERNATE) TRANSVERSE CONN (NON-FLANGED, LATCH TYPE, NON-WATERTIGHT). TYPE I ACCESS COVER (BOLTED). TYPE 2 ACCESS COVER (QUICK ACTING, FLAT-OVAL). TYPE I WIREMESH SCREENING (OPEN-END DUCT). TYPE 2 WIREMESH SCREENING (CONE TERMINAL). TYPE S WIREMESH SCREENING (BELLMOUTH TERMINAL). TYPL 4 WIREMESH SCREENING (SIDE-OF-DUCT). TYPE 5, WREMESH SCREENING (IN COAMING). DUCT REWFORCEMENT. NATIONAL SHIPBUILDING RESEARCH PROGRAM RECTANGULAR DUCT STANDARDS SIZE MARAD CONTS TODO DEAWING NO. ... 2-36233 4966-SK-006 SET SEALS HOWE 14113 or 31

- HOSE DUCT COMPONENTS DESIGNED, PARKICATED, AND S. W. FIRE PROTECTION REQUIREMENTS, AS DEFINED BY THE , (REF 4). NO CINOD) ALL NORD AR MARAD CONTR TODO DEAWING NO. 4966-SK-006 1 H2 81 4 01 5 BEN SENIS HONE

1. DEFINITION OF TERMS

WATERTIGHT - THOSE DUCT COMPONENTS DESIGNED, FABRICATED AND INSTALLED, TO OFFER THE VESSEL PROTECTION AGAINST FLOGDING FROM EITHER INSIDE OR OUTSIDE THE COMPONENT. THESE COMPONENTS WILL BE OF ALL WELDED CONSTRUCTION, AND SHALL HAVE LITHER WELDED TRANSPERSE JOINTS, OR BE COMMECTED WITH THE APPROPRIATE GASKETED TRANSPERSE JOINTS, OR BE COMMECTED WITH THE APPROPRIATE GASKETED FLANGED CONNECTIONS.

CLASS 'A' FIRE PROTECTION - THOSE DUCT COMPONENTS DESIGNED, FABRICATED, AND INSTALLED TO SATISFY CLASS 'A' FIRE PROTECTION REQUIREMENTS, AS DEFINED BY THE UNITED STATES COAST GUARD, (REF 4).

CLASS 'B' FIRE PROTECTION - THOSE DUCT COMPONENTS DESIGNED, FABRICATED, AND INSTALLED, TO SATISFY CLASS 'B' FIRE PROTECTION REQJIREMENTS, AS DEFINED BY THE UNITED STATES COAST GUARD, (REF 4).

"NON-WATERTIGHT" - THOSE DUCT COMPONENTS NOT DESIGNED TO BE WATERTIGHT. NON-WATERTIGHT DUCT COMPONENTS MAY BE EITHER AIR TIGHT OR NON-TIGHT, THE DIFFERENCE WATERTIGHT DUCT COMPONENTS ARE FARRICATED, SEALED, AND IRSTALLED, TO OFFER MIMINIAL HORMAL AIR LEARNAGE, WHILE AIRTIGHT COMPONENTS NOST USUALLY WITHSTAND A PRESSURE TEST TO ENSURE HILMAL LEARNAGE. IT IS EMPHASIZED THAT THERE SHOULD BE NO DIFFERENCE IN THE DESIGN OF AIRTIGHT AND NON-TIGHT COMPONENTS, EXCEPT FOR THE DEGREE OF SEALING REQUIRED TO PASS THE PRESSURE TEST.

DESIGNATIONS "D" AND "W" - UNLESS OTHERWISE MOTED, THE TERMS D, W, D1, W1, ETC., AS USED HEREIN REFER TO THE INSIDE CROSS-SECTIONAL DIMENSIONS OF DUCT COMPONENTS OR OPENINGS. EXCEPT FOR ELBONS AND OFFSETS, THE DESIGNATIONS D AND W FOR THE COMPONENT DIMENSIONS IS NOT SIGNIFICANT. FOR ELBONS, THE SIDE OF THE ELBON IN THE PLANE OF THE SIDE (THE HEEL, THROAT, OR WRAPPER) MUST BE DESIGNATED W, AND THE OTHER SIDE (THE HEEL, THROAT, OR WRAPPER) MUST BE DESIGNATED D.

ABBREVIATIONS AND DIMENSIONAL SYMBOLS:

ALL WORD ABBREVIATIONS ARE IN ACCORDANCE WITH REP. 2, EXCEPT FOR THE FOLLOWING:

RC = RADIUS CORMER C-C = CENTER TO CENTER

THE FOLLOWING LETTERS HAVE BEEN USED FOR DIMENSIONAL SYMBOLS:

R - RADIUS

L = LENGTH TR = THROAT RADIUS HR = HEEL RADIUS

HR = HEEL RADIUS
C = IN-LINE DIMENSION FOR PREPARED TRANSVERSE SEAM
S1, S2, S3 = SPLITTER RADII
D, D1, D2, W, W1, W2 = COMPONENT CROSS-SECTIONAL DIMENSIONS
A = ANGLE OF TURN, AMD DIMENSION FOR ACCESS PLATE
B = DIMENSION FOR ACCESS PLATE
X = DISPLACEMENT OF OFFSET CENTERLINE

2. STANDARD SIZES

THE TOTAL RANGE OF STANDARD SIZES IS SHOWN ON THE "STANDARD SIZES, MATERIAL REQUIRE-MENTS, AND MEIGHTS" TABLES. IT IS INTEMDED THAT THESE SIZES BE UTILIZED BY THE DESIGNER FOR ALL STRAIGHT DUCTING, ELBOWS, OFFSETS, ENDS OF TRANSFORMATIONS, AND COMMERCIONS.

(CONTD ON SH 5)

8 NONE SHIPBUILDING DUCT 4966-SK-006 RESEARCH PROGRAM STANDARDS

						HOTES (CONT'D)
			2.	(CO	mt'	D)
				A R	ECA	P OF THAT TABLE IS AS FOLLOWS:
				<u>D 0</u>	R W	(SHALL DIMENSION-INCHES) D OR W (LARGE DIMENSION-INCHES)
						4, 6, 8.
	٠					4, 6, 8,, 14.
						6, 8, 10,, 18.
						8, 10, 12,, 24.
						10, 12, 14,, 30.
		•				12, 14, 16,, 36.
						14, 16, 18,, 42.
	l					16, 18, 20,, 48.
						18, 20, 22,, 54.
						20, 22, 24.
						22, 24.
						24 24
			3.	BAS AND AND TO INC BE	ED W FA SUI REM USE	CH HIGHMENTAL CHANGES. THESE, AND THESE ALONE, CONSTITUTE THE "STANDARD AS PROPOSED REMEIN. IT IS EMPERALIZED THAT ALL SIZES NOT SHOWN ON TRAT ARE TO SE CONSIDERED AS "MON-STANDARD". WHERE IT IS NOT POSSIBLE TO UTILIZE THE STANDARD SIZES IN ANY PARTICULAR INSTANCE, D AND W DIMERSONS SHALL BE ON ONE-TROE INCREMENTAL CHANGES. IN NO CASE SHOULD PRACTICULAR VALUES OF D BE SPECIFIED, EXCEPT WHERE ROUIDMENT COMPETIONS SO REQUIRE. THE CONSTRUCTION BRICATION DRAWINGS (REF. 3), AND COMPUTER CUTPUT (REF. 1), HAVE BEEN DEVELOPED IT THE TWO-INCE INCREMENTAL SIZE STANDARD, WITH PROVISION FOR THE OME-INCE BUTTAL SIZES, IP NECESSARY. IT IS AGAIN STRESSED THAT THE "STANDARD SIZES" D WHEREVER POSSIBLE.
	Ä			GRA	DE :	1 (20 ga Steel) - Used for all non-watertight duct components whose largest excitonal dimension is 24° or less.
				GRA	DE :	2 (16 ga STEEL) - USED FOR ALL NON-MATERTIGHT DUCT COMPONENTS WHOSE LARGEST SECTIONAL DIMENSION IS GREATER THAN 24".
				GRA TIG	DE :	3 (11 ga STEEL) - USED FOR ALL DUCT COMPONENTS EXPOSED TO THE WEATHER, WATER- COMPONENTS, COMPONENTS SUBJECT TO CLASS 'A' FIRE PROTECTION REQUIREMENTS, AND ENTS WRICE MAY BE SUBJECT TO APPRECIABLE DAMAGE (OUTSIDE OF DRY CARGO HOLDS).
	\exists					4 (3/16" STEEL) - USED FOR ALL HORIZONTAL DUCT COMPONENTS IN DRY CARGO HOLDS.
				gra	OF.	5 (1/4" STEEL) - USED FOR ALL VERTICAL DUCT COMPONENTS IN DRY CARGO HOLDS. THE ABOVE DUCT MATERIAL GRADES SATISFY CLASS 'B' FIRE PROTECTION REQUIREMENTS.
	3		4.	MAT	F	AL QUANTITY REQUIREMENTS - BASIC COMPONENTS
	SCA1	5	=		ÀIO	THIS PANDRLET IS SUPPLEMENTED BY REFERENCES 1 AND 3. WHILE REFERENCE 1 LISTS MAINT OF THE DUCT COMPONENT MATERIAL QUANTITY REQUIREMENTS, THE FOLLOWING IMPORMATION IS ALSO NOTED:
	NONE.	2-36233	INO GARVI	RECTANG	NAL SHIP	THE MATERIAL REQUIRED FOR ANY PIECE OF STRAIGHT DUCT MAY BE APPROXIMATED BY THE FOLLOWING EQUATION (INCLUDING ALLOWANCES FOR TRANSVERSE CONNECTIONS AND LONGITUDINAL SEAMS):
-	+		-	N . V		(CONTD ON SH G)
	- 1		TORR BRAWING NO.	*	9	(SINIE ON SINIE)
I		\$:	000	ō	
	1	8	*	-	ES	
Į	_	4966-SK-006	ô	STA	2	
		8.	ē	Z	E	
	sutt 5 or 3	5		ILAR DUCT STANDARDS	3	
1	2			DS	60	
l	ع[486		UILDING RESEARCH PROGRAM	

S r

••

```
NOTES (CONT'D)
                          4. (CONT'D)
                                      M = \frac{(L+2)\chi(D+W+1)}{72}
                                      WHERE:
                                     M = NET MATERIAL REQUIREMENT IN SQUARE FEET W = "W" DIMENSION OF DUCT IN INCHES L = LENGTE \ OF \ DUCT \ IN INCHES
                                     THE NATERIAL REQUIRED FOR A TYPE 1, 2, OR 3, MON-TRANSFORMING ELBOW (WITHOUT SPLITTERS) MAY BE APPROXIMATED USING THE FOLLOWING EQUATION (INCLUDING ALLOWANCES FOR TRANSVERSE COMMECTIONS AND LONGITUDINAL SEAMS):
                                                                      M = \left[\frac{\lambda(29R+W) \times (D+W+2)}{8250}\right] + \frac{D+W}{36}
                                     WHERE:
                                 M = MET HATERIAL REQUIREMENT IN SQUARE FEET
A = ANGLE OF TURN IN DEGREES
N = 'W' DIMENSION OF RIBOW IN INCHES
D = 'D' DIMENSION OF RIBOW IN INCHES
TR = THROAT RADIUS OF RIBOW IN INCHES
                                     THE MATERIAL REQUIRED FOR A SPLITTER IN A TYPE 1,\ 2,\ {
m OR}\ 3, non-transforming elbow may be approximated using the following equation:
                                    M = \frac{D(SA+1)}{8250}
                                    WHERE:
                                    M = NET MATERIAL REQUIREMENT IN SQUARE FRET
S = SPLITTER RADIOS IN INCHES
D = 'D' DIMENSION OF RIBON IN INCHES
A = ANGLE OF TURN IN DEGREES
                                    THE MATERIAL REQUIRED FOR A TRANSFORMATION MAY BE APPROXIMATED USING THE POLLOWING EQUATION (INCLUDING ALLOWANCES FOR TRANSVERSE COMMECTIONS AND LONGITUDINAL SEAMS):
                                                   [D1 + D2) + (M1 + M2) \times (L+2) + 2L
                                    WHERE:
                                  H = NET NATERIAL REQUIRED IN SQUARE PERT

D1 = 'D1' DIMENSION OF TRANSFORMATION IN INCHES

D2 = 'D2' DIMENSION OF TRANSFORMATION IN INCHES

W1 = 'W1' DIMENSION OF TRANSFORMATION IN INCHES

W2 = 'W2' DIMENSION OF TRANSFORMATION IN INCHES

L = 'L' DIMENSION OF TRANSFORMATION IN INCHES

SINCE THE 'L' DIMENSION USED WILL ROBBALLY BE SLIGHTLY LESS THAN THE TRUE LENGTH OF

THE SIDES THE EQUATION IS AN APPROXIMATION, HONSVER, THE RESULTS WILL BE OF SUFFICIENT

ACCURACY TO SATISFY MOST REGULERIESTS. IN THIS RESPECT, IT IS RECOMMENDED THAT THE

SAME EQUATION BE USED FOR CALCULATING THE MATERIAL REQUIREMENTS OF TRANSFORMATIONS

BETWEEN RECTANGULAR AND HOW-RECTANGULAR SHAPES, WHICH RESULTS IN A SLIGHTLY HIGHER

THAN ACTUAL MATERIAL REQUIREMENT.
   BIVOS
             .
                                                                                                          (CONTO ON SH 7)
                                   RECTANGULAR
 NONE
                        1000
                                    DUCT
          4966-SK-006
                                               RESEARCH
                                   STANDARDS
10 Dienie
                       ¥0.
                                               PROGRAM
```

5. SPLITTER LOCATION

THE CHART IN THE BUFFALO FORGE CO. HANDBOOK "FAN ENGINEERING" SHALL BE USED TO DETERMINE ELBOW SPLITTER SPACING. (ENCEPT FOR THE DOUBLE-WALL TURNING VANES USED IN THE TYPE 4 REBOW, EQUAL-SPACED SPLITTERS WILL NOT PRODUCE THE MINIMUM ELBOW PRESSURE LOSS). SPLITTER LOCATIONS ARE ALSO LISTED IN REF 1.

6. TYPE 4 ELBOW (VANED)

THE VANED ELBOW SHOWN HAS BEEN DEVELOPED TO ACCEPT EITHER SHOP-PABRICATED OR CONGERCIALLY BOUGHT TURKING VANES AND VANE RUBRIES. THE TURKING VANES INDICATED ARE OF THE DOUBLE WALL TYPE, IN GROEN TO MINIMITE PRESSURE LOSS. THE VANES ARE AVAILABLE WITH AND WITHOUT ACCOUNTIC INSULATION RETWEEN THE WALLS. CARE MUST BE TAKEN THAT THIS TYPE OF ELBOW AS USED FOR ONLY 90°, NON-TRANSFORMING TURKS, SINCE THE VANES WILL NOT OTHERWISE PERFORM CORMICTLY. BECAUSE OF ITS SPECIALIZED MATURE, MINIMUM USE SHALL BE MADE OF THIS COMPONENT TYPE.

7. OFFSET TYPES 1 AND 2

THE USE OF ELBOW TO ELBOW OFFSETS ARE A FREQUENT OCCURENCE, AND SOME FABRICATION SHOPS PREFER TO MAKE THESE AS ONE COMPONENT. SINCE THEY ARE MADE IN OME PIECE, THERE IS NO MEED FOR A 'C' DIMENSION ALLOWANCE RETWEEN THE TWO OFFSETTING ELBOWS. HOWEVER, GUIDANCE IN THEIR USE MUST BE GREATHED FROM THE PARRICATION SHOP, CONCENNING THEIR PREFERENCES, LIMITATIONS DUE TO SHEET NETAL STOCK, THE MAXIMUM SIZE OF COMPONENT WHICH THEY FABRICATE AS ONE PIECE, ETC.

IF USED, THE OFFSETS HAVE BEEN DEVELOPED TO BE SELECTED ON 1" INCREMENTAL CHARGES IN DUCT CENTERLINE LOCATION. FOR DESIGN PURPOSES, THE TOTAL OFFSET LENGTH MAY BE CALCULATED FROM THE EQUATIONS GIVEN. AS NOTED, THIS LENGTH DOES NOT INCLUDE THE 'C' DIREMSION ALLONANCE REQUIRED ON EACH SMD OF THE CONFLETE OFFSET.

8. TRANSFORMATIONS


THE SELECTION OF TRANSFORMATION CONFIGURATIONS AND LENGTH IN MANY CASES WILL DEPEND ON THE SPACE AVAILABLE. AS MAY HE SEME FROM THE PRESSURE DROP DATA REFERENCED HEREIN, THE TOTAL EMERGY LOSS IS DEFENDENT UPON THE ANGLE OF CONVERGENCE OR DIVERGENCE. WHILE A WIDE RANGE OF CONVERGENCE ANGLES WILL RESULT IN APPROXIMATELY THE SAME EMERGY LOSS, THIS IS NOT TRUE FOR A DIVERGING ANGLE, WHOSE EMERGY LOSS VARIES CONSIDERABLY. IT IS THEREFORE IMPORTANT TO SELECT A DIVERGING TRANSFORMATION WHOSE LENGTH WILL MINIMIZE SUCH LOSS IF POSSIBLE.

IN ADDITION TO THE ABOVE, IF A FLAT-SIDED TRANSFORMATION IS SELECTED, THE TOTAL LOSS WILL CONSIST OF THE TRANSFORMATION LOSS, FLUE THE SMALL-ANGLE MITER TURN LOSSES WHICH WILL EXIST AT EACH END OF THE TRANSFORMATION, DUE TO THE CHANGE IN DIRECTION

9. BRANCE TAKE-GFTS

THE CHOICE BETWEEN LOCATING A BRANCH TAKE-OFF ON STRAIGHT DUCT, OR ON A TRANSPORMATION, WILL DEPEND ON MANY CONSIDERATIONS, INCLUDING SUCH ITEMS AS BRANCH/MAIN AIR QUANTITY RATIOS, WHITHER THE TAKE-OFF IS LOCATED ON THE SUCTION OR DISCHARGE SIDE OF THE FAN, SPACE AVAILABILITY, ETC. IN GENERAL, IT IS RECOMMENDED THAT THE TAKE-OFF BE LOCATED ON STRAIGHT DUCT IF THE BRANCH/MAIN AIR QUANTITY RATIO IS 10 PERCENT OR LESS. IT IS ALSO RECOMMENDED THAT THE BRANCH/MAIN AIR VELOCITY RATIOS BE SELECTED TO MINIMIZE PRESSURE BROF LOSSES.

LOCATION OF TAKE-OFF (GEOMETRIC CONSIDERATIONS)



>-7

10. DUCT REINFORCEMENT

IN ORDER TO DETERMINE THE NEED FOR DUCT REIMFORCEMENT, THE DESIGNER MUST FIRST DETERMINE THE STATIC PRESSURE EXISTING WITHIN THE DUCT AT VARIOUS POINTS. THE FOLLOWING DATA WILL AID IN THAT DETERMINATION:

STATIC PRESSURE AT ANY POINT ON SUCTION SIDE OF FAN SP = -(TPL+VP)

STATIC PRESSURE AT ANY POINT ON DISCHARGE SIDE OF FAM SP = FTP - (TPL+VP)

SP = STATIC PRESSURE AT ANY POINT 'a'
FTP = FAN TOTAL PRESSURE (SYSTEM CONSTANT)
TPL = TOTAL PRESSURE LOSS TO POINT 'a' (AS CALCULATED
FROM THE SUCTION SIDE TERMINALS.)

VP - VELOCITY PRESSURE AT POINT 'a'

WHERE ANY OF THE FLANGED TYPE TRANSVERSE CONNECTIONS ARE USED, THEY MAY BE CONSIDERED AS DUCT REINFORCEMENT. (THIS IS ALSO TRUE OF THE S-CLIP WITH REINFORCING LEG.)

11. CONNECTIONS TO FLAT-OVAL OR RADIUS CORNER COAMINGS

IT IS RECOMMENDED THAT THE USE OF TYPES 2, 5, AND 7 FLANGE CONNECTIONS BE MINIMIZED IN FAVOR OF TYPES 1, 3, 4, AND 6 FLANGE CONNECTIONS. THE EXTENT TO WHICH THIS MAY BE ACCOMPLISHED MILL DEPEND UPON THE ACCEPTABILITY OF THE ABRUFT ENLANGEMENT AND/OR CONTRACTION EMERGY LOSSES WHICE RESULT. WHERE THE DUCT SIZE AND THE COAMING SIZE ARE SUCH THAT A TRANSFORMATION IS REQUIRED IN ANY CASE, IT, IS RECOMMENDED THAT THE TRANSFORMATION BE EXTREM TYPE 1 OR 4. THIS WILL ALLOW THE OF TYPES 1, 3, 4, AND 6, FLANGE CONNECTIONS BETWEEN THE COAMING AND TRANSFORMATION, AND WILL ALSO DEPEND UPON THE ACCEPTABILITY OF THE RESULTANT ABRUPT EMERGY LOSSES.

12. ALLOHANCE FOR TRANSVERSE CONNECTIONS

THE LETTER 'C' HAS BEEN ASSIGNED TO INDICATE WHERE THE DESIGNER MUST LEAVE ALLOWANCES FOR TRANSVERSE CONNECTIONS. 'C' REPRESENTS THE IN-LINE DIMENSIONS FOR THE PREPARED CONNECTION TYPE USED ON THE END OF THAT COMPONENT. IT DOES NOT REPRESENT THE TOTAL MATERIAL WHICH MUST BE LEFT ON THE COMPONENT FOR THE CONNECTION. THERMFORE, WHEN USING ONE OF THE TRANSVERSE TIPE CONNECTIONS, THE DIMENSION WHICH THE DESIGNER MUST ALLOW FOR WILL EQUAL THE COMBINATION OF ANY OF THE TWO TIPES SELECTED FOR THE TOTAL CONNECTION.

EXAMPLE:

TOTAL CONNECTION = TYPE 1 CONNECTION MATED TO TYPE 4 CONNECTION TOTAL ALLOWANCE = 1/4" + 1-1/4" = 1-1/2"

THE FOLLOWING TABLE INDICATES THE TOTAL IN-LINE ALLOMANCE WHICE MUST BE PROVIDED FOR BY THE DESIGNER FOR ALL OF THE VARIOUS CONNECTION TIPES AND COMBINATIONS WHICH MAY OCCUR. ALL DIMENSIONS GIVEN ARE IN INCRES. A ZERO ENTRY INDICATES THAT THE CONNECTION COMBINATION IS POSSIBLE, AND THAT HO ALLOMANCE IS INCRESSRY. A DASE (-) ENTRY INDICATES THAT THE CONNECTION CONSIDERATION IS NOT POSSIBLE. SHOP PREFERENCES MUST BE ESTABLISHED PRIOR TO UTILIZING ANY OF THE TRANSVERSE CONNECTION TIPES.

١.						
1438	8	\$120		IVN	(CONTD ON SH	9)
NONE	2-36233	MARAB CONTR	RECTANGULAR	NATIONAL SHIPPL		
111111111111111111111111111111111111111	4966-SK-006	1000 BLAWING NO.	LAR DUCT STANDARD	SHIPBUILDING RESEARCH PRO		

12. (CONT'D)

	12. (0	ONT DI											1 1	1
COUNT	SVERSE ECTION PE	1	2	3	4	5	.6	7	8	9	10	11	12 (BASIC)	12 (ALTH)
	1	1/2	-	1/2	1-1/2		1/4	-	- 4	-	-	-	-	-
	2	-	-	-	-	1-1/2	-	1/4	-	-	-		-	
	3	1/2	-	ī	1-1/2	-	1/4	-	-	-	-	<u> </u>	<u> </u>	-
	4	1-1/2	-	1-1/2	2-1/2	-	1-1/4	-	-		-	<u> </u>		
	5		1-1/2	-	-	-	-	-	-	-	-	-	<u> </u>	<u> </u>
	6*	1/4	-	1/4	1-1/4	-	0	-	-	-	<u> </u>	<u> -</u>	<u> -</u>	-
	7*	-	1/4	-	-	-	-	-	-	-	-	-	<u> -</u>	<u> </u>
	8	 -	-	-	-	-	-	-	0	-		<u> </u>	<u> </u>	-
	<u> </u>	+-	-	-	-	1-	-	-	-	1	<u> </u>	<u> </u>	-	<u> </u>
	10	+-	├ -	! -	 -	1 -	-	-	-	-	1	<u> </u>	<u> -</u>	
	11	+-	 	1 -	-	1-	-	-	-	_	-	1.	<u> -</u>	-
		+-	+-	十-	-	1 -	-	1 -	-	-	-	-	1/2	
_	(ALTN)	+-	+-	-	†=	1-	1 -	-	E	-	-	<u> </u>	<u> </u>	1

* - THESE CONNECTION TYPES HAVE STRENGTH LIMITATIONS. THEIR USE IS THEREFORE LIMITED, AND SUCH USE IS A SHOP DECISION ON A CASE BASIS.

THE 'C' DESIGNATION HAS REEN INDICATED ON BOTH ENDS OF COMPONENTS REQUIRING SAME.
DIFFERENT TRANSVERSE CONNECTIONS TYPES MAY BE SELECTED FOR EACH END OF THE COMPONENT.
IT IS RECOMMENDED THAT THE DESIGNER INDICATE FLANGE TYPE CONNECTIONS ONLY WERE
THESE ARE ASSOLUTELY REQUIRED, SUCE AS AT CONNECTIONS TO COASINGS OR EQUIPMENT, AND
HAKE ALLOWANCE FOR THE NON-FLANGE TYPE CONNECTIONS ELSEWHERE. IF THE TRANSVERSE
SEAMS ARE TO BE WELDED, NO ALLOWANCE IS NECESSARY.

(CONTD ON SH 10)

10 6 111115	17 SCALE NONE	3
4966-SK-006	2-36233	
SIZE MARAD CONTR TODD DRAWING NO.	ITE MARAD CONTR	-1
AR DUCT STANDARDS	. RECTANGULAR DUCT	
NATIONAL SHIPBUILDING RESEARCH PROG	ATIONAL SHIPBU	71

I

?

13. TYPE 12 CONNECTION (LATCH TYPE)

WHEN UTILIZING EITHER OF THE LATCH TYPE CONNECTION DESIGNS, CARE MUST BE TAKEN TO ENSURE THAT THE LATCH ITSELF IS LOCATED ONLY ON A COMPONENT WHOSE SIDES ARE FLAT AND
PARALLEL TO THE COMPONENT'S CENTERLINE. THIS PROMIBITS ITS USE ON THE CURVING PORTIONS OF AN ELBOW (THE HEEL AND THROAT), AND ON THE SLIPFING SIDES OF A TRANSFORMATION.
WHILE THIS RESTRICTION IS MAINLY OF INTEREST TO THE FARMICATION ACTIVITIES, IT IS MOTED
HEREIN FOR INFORMATION. IT IS ALSO RECOMMENDED THAT THIS TYPE CONNECTION NOT BE UTILIZED ON COMPONENTS WHOSE LARGEST CROSS-SECTIONAL DIMERSION IS GREATER THAN 36".

THE FOLLOWING RECONCENDATIONS ARE MADE IN ORDER THAT THE VENTILATION SYSTEM DESIGN MINIMIZE PARTICATION AND INSTALLATION COSTS WHEREVER POSSIBLE.

- A EVERY ATTEMPT SHOULD BE MADE TO UTILIZE THE "STANDARD SIZES" AND COMPONENT COMPIGURATIONS SHOWN HEREIN TO MINIMIZE THE REQUIREMENT FOR SPECIAL PITTINGS.
- B WHERE PRESSURE DROP CONSIDERATIONS PERMIT, THE USE OF TRANSFORMATIONS SHOULD BE MINIMIZED AS POLLOWS:
 - USE FLANGE TYPES 1, 3, 4 AND 6 IN LIEU OF FLANGE TYPES 2, 5 AND 7, TO REDUCE THE REQUIREMENT FOR TRANSPORMATION TYPES 2 AND 5.
 - WHERE POSSIBLE, COAMING CROSS-SECTIONAL DIMENSIONS SHOULD BE THE SAME AS THE COMMETTING DUCT DIMENSIONS SO THAT THE ABOVE MAY BE ACCOMPLISHED MITSOUT TRANSFORMATION.
 - ONE DUCT SIZE SHOULD BE UTILIZED AS MUCH AS POSSIBLE ON ANY PARTICULAR DUCT RUN TO REDUCE THE NECESSITY OF TRANSPORMATIONS.
- C WHERE PRESSURE DROP CONSIDERATIONS PERMIT, THE USE OF AS MANY COM-POMENTS OF THE SAME SIES AND CONFIGURATION ON A PARTICULAR DUCT RUN WILL HIMINIZE PATTERN DEVELOPMENT, AND THE PARRICATION OF MORE COM-POMENTS THAN ARE MECESSARY.
- D WHERE PRESSURE DROP CONSIDERATIONS PERMIT, BRANCE TAKE-OFFS SHOULD BE UTILIZED IN LIEU OF DUCT SPLITS.

15. PRESSURE DROP LOSSES - RECOMMENDED DATA SOURCES:

- U.S. HAVY DESIGN DATA SHEET DDS 512-1

 ELBOW TYPES 1, 2 AND 3, AND OFFSET TYPES 1 AND 2.

 CONVERGING AND DIVERGING TRANSFORMATIONS.

 MAIN LOSS DUE TO BRANCH TARK-COFF (MAIN SIZE CHANGING)

 WITH THE POLLOWING CONVECTIONS.

ON DISCHARGE SIDE OF FAN

LOSS = MANY LOSS X (BRANCH AIR QUANTITY OF TAKE-OFF)

(CONTD ON SH 11) 8718 NONE SHIPBUILDING 1000 4966-38-006 RESEARCH STANDAR 100/111885 PROGRAM

15. (CONT'D)

ON SUCTION SIDE OF FAN ON SUCTION SIDE OF FAN BRANCH AIR QUARTITY
LOSS = HAVY LOSS X (1/2 HAIN AIR QUARTITY DOWNSTREAM OF TAKE-OFF)

BRANCE AIR QUANTITY SHOULD NOT BE GREATER THAN:
50 PERCENT OF MAIN AIR QUANTITY UPSTREAM OF
TAKE-OFF ON DISCHARGE SIDE OF FAM.
50 PERCENT OF MAIN AIR QUANTITY DOWNSTREAM OF
TAKE-OFF ON SUCTION SIDE OF FAM.

U. S. HAVY DUCT SIZE PACTOR WHEEL . STRAIGHT DUCT PRICTION LOSSES.

BUFFALO FORGE COMPANY HANDBOOK "FAN ENGINEERING"

• TYPE 4 ELBON (VANED), WITH SUITABLE CORRECTION FOR ASPECT RATIO AS GIVEN THEREIN.

• HAIN LOSS DUE TO BRANCE TAKE-OFF (CONSTANT MAIN SIZE) ON SUCTION SIDE OF PAN.

ASHRAE HANDSOOK OF FUNDAMENTALS

• TRANSFORMATIONS - EQUAL AREA.

• ABRUFT ENLANGEMENTS.

• ABRUFT CONTRACTIONS.

• BRANCH TAKE-OFF LOSSES ON DISCHARGE SIDE OF FAN.

• MAIN LOSS DUE TO BRANCE TAKE-OFFS (CONSTANT MAIN SIZE) ON DISCHARGE SIDE OF FAN.

16. COMPONENTS SHOWN HEREIN HAVE REEN ASSIGNED "APPLICABILITY" RATINGS, AS FOLLOWS.
THISE INDICATE THE RIGHEST DEGREE OF APPLICATION IN WHICH THE SPECIFIC COMPONENT
MAY BE USED, UNDER THE VARIOUS REGULATORY BODIES. WHERE THE COMPONENTS OF
DIFFERENT "APPLICABILITIES" ARE CONNECTED, THE LOWER RATING MUST BE GIVEN TO THE
COMPUTATIONS.

COMPONENT	MATERIAL	APPLICABILITY
STRAIGHT DUCT TYPES 1 TO 4 ELBOWS TYPES 1 AND 2 OFFSETS TYPES 1 TO 6 TRANSFORMATIONS	11 ga OR THICKER	WATERTIGET CLASS A FIRE PRO- TECTION RAT PROOF
	16 ga OR 20 ga	NON-MATERTIGET CLASS B FIRE PRO- TECTION RAT PROOF
TYPES 1 TO 10 BRANCE TAKE-OFFS	11 ga OR THICKER, WITH THE BRANCH AND MAIN WELDED TOGETHER	WATERTIGHT CLASS A FIRE PRO- TECTION RAT PROOF
	16 ga OR 20 ga	MON-WATERTIGHT CLASS B FIRE PRO- TECTION RAT PROOF

(CONTD ON SHIZ)

- 1			١
1	succession 3	SONE NONE	Š
	4966-SK-006	2-36233	
T	SIZE MARAD CONTR TODO DRAWING NO.	MARAD CONTR	=
•	LAR DUCT STANDARDS	RECTANGULAR DUCT	
12	VATIONAL SHIPBUILDING RESEARCH PROGR	ONAL SHIPPL	À

	16.	(CONT	'D)				1
		СОИРО	HENT			MATERIAL	APPLICABILITY
	COME	nouth Ing -of-du					TIGHTNESS-NOT APPLICABLE PIRE PROTECTION - NOT APPLICABLE RAT PROOF - ONLY WITH 1/2" WIRE MESH SCREENING
	TYPE	1 ACC	ESS	COVER	11	ga OR THICKER	WATERTIGHT CLASS A FIRE PROTEC- TION RAT PROOF
					10	6 ga	NOM-WATERTIGHT CLASS B FIRE PROTEC- TION RAT PROOF
	TYPE	2 AC	ESS	COVER			HON-WATERTIGHT CLASS B FIRE PROTEC- TION RAT PROOF
	TYPI	s 1, 3	2, 3, E CO	, and 8 MMECTIONS			WATERTIGHT CLASS A PIRE PROTEC- TION RAT PROOF
	TYPI	TYPES 4 TO 7, AND 9 TO 12 TRANSVERSE CONNECTIONS					NON-WATERTIGHT CLASS B FIRE PROTEC- TION RAT PROOF
	DUCT REINFORCEMENT						NON-WATERTIGET CLASS B FIRE PROTECTION RAT PROOF
7.	TYPES 1 TO 5 LONGITUDINAL SEAMS			SEAMS		***	MON-WATERTIGHT CLASS B FIRE PROTECTION RAT PROOF
	TYP	ES 6 A GITUDI	ND 7 NAL	SEAMS		••	WATERTIGHT CLASS A FIRE PROTEC- TION RAT PROOF
7							
7							
=		_					•
	3 =		2 >				
NONE	2-36233	RECTANGU	ATIONAL SHIPPL	•			
4700-00-000	4966-9K-006	GULAR DUCT STANDARDS	SHIPBUILDING RESEARCH PROGRAM		1 <u>.</u>];	; .
		AR DS	PROG	. ,			

	STANDARD SIZES, MATERIAL	requirement	TB, AND WEI	Girts				TANDARD SIZES, MATERI	AL REQUIREMEN	ITS, AND WE	IGHTS (COM	r'D)		
4170	SIZE. MATERIAL REQUIRED MEIGHT FER LIMEAR FOOT (LAS)							T						
(INCHES)	PER LINEAR POOT FOR STRAIGHT BUCT (FT ²)	GRADE 1 (20 ga)	(16 ga)	(11 ga)	(3/16")	GEABE 5 (1/4") .	SIZE (INCHES)	MATERIAL REQUIRED FEB LIMEAR FOOT PO STRAIGHT BUCT (PT	GMADE 1	GRABE 2 (16 ga)	GRADE 3 (11 ga)	GRADE 4 (3/16")	GRADE 5 (1/4")	
2 x 4	1.0	1.66		5,16	7.81	10.36	10 × 24	5.67	9.39	+	29.23	44.26	58.72	
2 x 6	1.33	2,20	•	6.86	10.38	13.77	10 x 26	6.0		15.94	30,94	46.84	62.14	
2 x 8	1.67	2,77		8.61	13.04	17.29	10 x 28	6.33	-	16.81	32.64	.49.41	65.55	
		ļ					10 x 30	6.67		17.72	34,39	52.07	69.07	
4 x 4	1.33	2,20	<u> </u>	6.86	10.38	13.77				1		1	1	
4 x 6	1.67	2,77	<u> </u>	8.61	13.04	17.29	12 x 12	4.0	6.62		20,62	31.22	41.42	
4 x 8	2.0 '	3,31	<u> </u>	10.31	15.61	20,71	12 × 14	4,33	7.17		22,33	33.80	44.84	
4 x 10	2,33	3,86	<u> </u>	12.01	18.19	24,13	12 × 16	4.67	7.73		24.08	36.45	48.36	
4 x 12	2.67	4,42	-	13.77	20.84	27,65	12 x 18	5.0 '	8.28		25.78	39.03	51.78	
4 x 14	3.0	4.97	<u> </u>	15.47	23,42	31.07	12 x 20	5.33	8.83		27.40	41,61	55,20	
			<u> </u>				12 x 22	5.67	9.39		29,23	44.26	58.72	
6 x 6	2.0	3,31	<u> </u>	10,31	15.61	20.71	12 × 24	6,0	9.94		30.94	46.84	62,14	
6 x 8	2.33	3,86	<u> </u>	12,01	18,19	24.13	12 x 26	6,33	-	16,81	32,64	49.41	65.55	
6 x 10.	2.67	4.42	<u> </u>	13.77	20.84	27.65	12 x 28	6.67	-	17,72	34.39	52.07	69.07	
6 x 12	3.0	4,97	<u> </u>	15,47	23,42	31,07	12 x 30	7.0	-	- 18,59	36.09	54.64	72.49	
6 x 14	3.33	5.51	-	17.17	25.99	34,49	12 x 32 ·	7.33	-	19.47	37.79	57,22	75.91	
6 x 16	3,67	6.08		18.52	28,65	38.01	12 × 34	7.67	-	20.37	39.55	59.87	79.43	
6 x 18	. 4.0	6,62	<u> </u>	20,62	31.22	41,42	12 x 36	8.0		21,25	41,25	62.45	82,85	
8 × 8	2,67	4.42	 	13.77	20.84	27.65	14 x 14	4.67	7.73	 	24.08	36.45	 	
8 x 10	3.0	4.97		15.47	23,42	31.07	14 x 16	5.0	8.28	 	25.78	39.03	48.36	
8 × 12	3.33	5.51		17-17	25.99	34.49	14 × 18	5.33	8.83	 			51.78	
8 x 14	3.67	6.08		18.92	28.65	36.01	14 × 20	3.67	9,39	 :	27.48	44.26	55.20 58.72	
8 x 16	4.0	6.62		20.62	. 31.22	41,42	14 x 22	6.0 .	9.94	 	30.94	46.84	62.14	
8 x 18	4.33	7,17		22.33	33.80	44.84	14 x 24	6.33	10.48	 	32,64	49.41	65.55	
8 x 20	4.67	7.73		24.08	36.45	48.36	14 x 26	6.67		17.72	34.39	52.07	69.07	
8 x 22	5.0	8.28	•	25.78	39.03	51.78	· 14 x 28	7.0	-	18.59	36.09	54.64	72.49	
8 x 24	5.33	8.83	•	27.48	41.61	35.20	***************************************					<u></u>		
		•						-						
10 x 10	3.33	5.51	-	17.17	25.99	34.49		N	ATIONAL	SHIPBUIL	DING RE	SEARCH P	ROGRA	
10 x 12	3.67	6,08		18.92	28.65	36.01		1	RECT	NGILLA		STANDA	. 04	
10 x 14	4.0	6.62		20,62	31.22	42,42			n 1 0 1 /		~ 0001	SIANDA	* A2	
10 x 16	4.33	7.17	•	22.33	33.00	44.84		Ţ.	IZE MARAD	CONTE TO		HG NO.		
10 x 18	4.67	7.73		24.08	36,45	48.36								
10 x 20	5.0	8,28		25.78	39.63	51.78			2-36	233	4966-	9K-006		
10 x 22	5.33	8.83	Ŀ	27.48	41.61	55.20		ARV S	CALE NONE			5 HE 6 T	130.31	

STANDARD SIZES, MATERIAL REQUIREMENTS, AND METGHTS (COMT'D) WEIGHT FEE LINEAR FOOT (LES)									
SIZES (INCHES)	MATERIAL REQUIRED PER LINEAR FOOT FOR STRAIGHT DUCT (FT ²)	GRADE 1 (20 ga)	GRADE 2 (16 ga)	CRADE 3 (11 ga)	GRADE 4 (3/16")	GRADE 5 (1/4")			
14 x 30	7,33	-	19,47	37.79	57.22	75.91			
14 x 32	7,67		20,37	39.55	59.87	79.43			
14 × 34	8.0	•	21.25	41.25	62,45	82.85			
14 x 36	8,33	-	22.12	42,95	65.02	86.27			
14 × 38	8.67	•	23.03	44.70	67.68	89.79			
14 x 40	9.0	-	23,90	46,40	70,25	93.20			
14 × 42	9.33		24,78	48,11	72,83	96,62			
16 x 16	5.33	8.83		27.48	41.61	55,20			
16 x 18	5.67	9.39	-	29;23	44.26	58.72			
16 x 20	6,0	9.94		30.94	46.84	62.14			
16 x 22	6.33	10.48		32.64	49.41	65.55			
16 x 24	6,67	11.05	-	34.39	52.07	69.07			
16 x 26	7.0		18.59	36.09	54.64	72.49			
16 × 28	7.33		19.47	37.79	57,22	75.91			
16 x 30	7.67	٠.	20,37	39.55	59,87	79.43			
16 x 32	8.0	-	21,25	41.25	62,45	82.85			
16 x 34	8.33	-	22,12	42.95	65.02	86.27			
16 × 36	8,67	-	23,03	44.70	67.68	89.79			
16 x 38	9.0		23,90	46.40	70.25	93.20			
16 x 40	9,33	-	24.78	48.11	72.83	96.62			
16 x 42	9.67	-	25.68	49.86	75.48	100.14			
16 x 44	10.0	-	26.56	51.56	78,06	103.56			
16 × 46	10.33	-	27.44	53.26	80.64	106.98			
16 x 48	10.67	•	28,34	55.01	83,29	110.50			
18 × 18	6.0	9,94	 	30.94	46.84	62.14			
18 x 20	6,33	10,48	T .	32.64	49.42	65.55			
18 × 22	6.67	11.05	1 -	34.39	52.07	69.07			
18 x 24	7.0	11.59	-	36.09	54.64	72.49			
18 × 26	7,33	-	19,47	37.79	57.22	75.91			
18 x 28	7.67		20.37	39.55	59.87	79.43			
18 x 30	8.0	•	21.25	41.25	62.45	82.85			
18 x 32	8.33		22.12	42.95	65.02	86.27			
18 x 34	8.67		23,03	44.70	67,68	89.79			
18 x 36	9.0	T -	23.90	46,40	70.25	93.20			

STANDARD SIZES, NATERIAL REQUIREMENTS, AND WEIGHTS (CONT'D										
	HATERIAL REQUERED	MEIGHT PER LINEAR POOT (LBS)								
Size (Inches)	PER LINEAR FOOT FOR STRAIGHT DUCT (PT ²)	GRADE 1 GRADE 2 GRADE 3 (10 ga)		GRADE 4 (3/16")	GRADE 5 (1/4")					
18 x 38	9,33	•	24.78	40.11	72.83	96.62				
18 × 40	9.67	•	25.68	49.86	75.48	100.14				
18 × 42	10.0	•	26,56	51.56	78.06	103.56				
18 × 44	10,33	•	27.44	53,26	80.64	106.98				
18 × 46	10.67		28.34	55.01	83.29	110.50				
18 × 48	11.0		29,22	56.72	85.87	113.92				
18 x 50	11,33		30,09	58.42	88,44	117.33				
18 x 52	11,67	•	31.0	60,17	91.10	120.85				
18 x 34	12.0	-	31.87	61.87	93.67	124.27				
20 x 20	6.67	11.05	-	34,39	52.07	69.07				
20 x 22	7.0	11.59		36.09	54.64	72.49				
20 x 24	7.33	12.14		37.79	57.22	75.91				
22 x 22	7.33	12.14	•	37.79	57.22	75.91				
22 x 24	7.67	12.70	-	39.55	59.87	79.43				
24 x 24	8.0	13.25	-	41.25	62,45	82.85				

ALL WEIGHTS ARE BASED ON GALVANIZED STEEL (BITHER BEFORE OR AFTER FABRICATION).

MATERIAL QUANTITIES AND WEIGHTS AS LISTED ARE BASED ON WELDED LONGITUDINAL SEAMS. IF THE 20 ga AND 16 ga DUCTS ARE TO HAVE RETHER PITTSBURCH SEAMS, OR SKAP-LOCK SEAMS, THE FOLLOWING CORRECTIONS SHOULD BE MADE:


20 ga -- ADO .15 FT² OF HATERIAL FOR EACH LINEAR FOOT OF SEAM, -- ADO .25 LBS FOR EACH LINEAR FOOT OF SEAM, -- ADD .15 FT² OF HATERIAL FOR EACH LINEAR FOOT OF SEAM, -- ADD .40 LBS FOR EACH LINEAR FOOT OF SEAM,

SEE NOTE NO. 3 FOR EXPLANATION OF THE VARIOUS GRADE MATERIALS.

	MATI	ONAL SHIPS	UILDING RESEARCH PROG	RAM
		RECTANGU	LAR DUCT STANDARDS	
	5129	MARAD CONTE	TODO DEAWING NO.	
	-	2-36233	4966-SK-006	
1 1 444	3541	NONE	I SMESTIL OF	뉇

RADIUS CONNER SELECTION

THE POLLOWING TABLE HAS BEEN PREPARED FOR THE PURPOSE OF SELECTING THE RADIUS COMMERS REQUIRED FOR COMMINGS PENETRATING STRUCTURE AND IT IS INTERDED THAT IT BE UTILISED FOR ALL SUCH PRINTINGATIONS.



SMALL CROSS-SECTIONAL DIMENSION OF COAMING	AVAILABLE RADIUS CORNERS (INCHES)			
D OR W (INCHES)	nì.	P2	123	M
2	11			<u> </u>
4	1	2		-
6	11	,	<u> </u>	
. 8	1	2	4	<u> </u>
10	2		3	<u> </u>
32	2	4	6	<u> </u>
14	2	4	<u> </u>	<u> </u>
16	2	4	6	
18	3	5	1	, ,
20	3	5	1	10
22	3	6	8	11
24	1	6	9	12

RI-THE MINIMUM RADIUS CORNER FOR THE DUCT SIZE GIVEN AND SHOULD BE UTILIZED IN ALL CASES UNLESS STRUCTURAL STRENGTH CONSIDERATIONS REQUIRE A LARGER RADIUS.


R2,R3,R4-OTHER RADIUS CORNERS AVAILABLE FOR THE DUCT SIZE GIVEN. WHERE STRUCTURAL CONSIDERATIONS REQUIRE THAT A RADIUS LARGER THAN R1 BE USED, THE SMALLEST ACCEPTABLE R SHOULD BE SELECTED FROM THESE.

THE USE OF THE SMALLEST ACCEPTABLE R IS RECONCENDED, TO ALLOW THE ELIMINATION OF SPECIAL TRANSFORMATIONS BETWEEN THE COMMING AND DUCT.


ALL RADIUS CORNERS USED MUST BE IN WHOLE MUMBERS (1", 2", 3", ETC), TO SUIT THE FLANGE BOLTING PATTERNS.


CROSS-SECTIONAL AREAS


THE FOLLOWING CHART DEPICTS THE EXTENT OF AREA VARIATION FOR THE STANDARD DUCT SIZES, AND HAS NEWN INCLUDED FOR REFERENCE PURPOSES. THE VERTICAL AXIS REFREENTS THE DUCT SMALL CROSS-SECTIONAL DISSIBILION. THE HEAVY HOULZONFAL LINES INDICATE THE BANCE OF CROSS-SECTIONAL AXIA ORTAINMER BY HOLDING THE MALL DIMBERGING CONSTANT, AND PRINTITIES THE OTHER DIMBERGING THE PRINTITIES THE DUCKE PRINTING THE DUCKE PRINTING THE DUCKE PRINTING THE DUCKE PRINTING THE TABLE OF "STANDARD SIZES, NATURAL REQUIREMENTS AND WRIGHTS".




NATIONAL SHIPBUILDING RESEARCH PROGRAM RECTANGULAR DUCT STANDARDS ... SIZE MARAD CONTE TODO DRAWING NO. 4966-6K-006 BEY SEALS HONE Succ15.01 3











NUMBER OF SPLITTERS = O OR 2. TR = W/2. MIN W = 4 " X = CENTERLINE OFFSET IN ONE-INCH INCREMENTS UP TO 2W MAX. MIN A (WITHOUT SPLITTERS): 15 . MIN A (WITH SPLITTERS) = 30. L = J(4-W-X)X

PREFERRED USAGE: WHERE OFFSET IS DESIRED AND SPACE AVAILABILITY COES NOT PERMIT FULL-THROAT ELBOWS. SEE NOTE 7 FOR LIMITATIONS, SEE NOTE 5 , OR REF I, FOR SPLITTER RADII SI AND S2.







TYPE I OFFSET (FULL-THROAT RADII)

NUMBER OF SPLITTERS = O. TR = W. X - CENTERLINE OFFSET IN ONE-INCH INCREMENTS UP TO 3W MAX. MINIMUM A = 15" L = (6W-X)X

PREFERRED USAGE:

IN ALL CASES WHERE OFFSET IS REQUIRED NATIONAL SHIPBUILDING RESEARCH PROGRAM AND SPACE AVAILABILITY PERMITS FULL-THROAT ELBOWS. SEE NOTE 7 FOR LIMITATIONS.






TYPE 4 ELBOW (VANED)


DOUBLE WALL VANES, VANE SPACING = 2". H= W+4", ANGLE OF TURN = 90° ONLY. MINIMUM W = 4". MINIMUM D = 4".

PREFERRED USAGE:

ONLY WHERE STABILIZATION OF AIR FLOW DOWNSTREAM OF TURN IS REQUIRED SEE NOTE 6 FOR VANE INFORMATION AND LIMITATIONS.

	5124	MARAD CONTR	TODD DRAWING NO.	
	8	2-36233	4966-SK-006	
٧	BEALL	NONE	2 HE 8 1 8 D	31







TYPE 3 TRANSFORMATION (SYMMETRICAL)

PREFERRED USAGE :

IN ALL CASES WHERE TRANSFORMATION IS REQUIRED BETWEEN RECTANGULAR AND ROUND COMPONENTS.
SEE NOTE 8 FOR LIMITATIONS.







TYPE 2 TRANSFORMATION (SYMMETRICAL)

PREFERRED USAGE:

ONLY WHERE PRESSURE-DROP CONSIDERATIONS DO NOT ALLOW USE OF FLANGE TYPES 3, AND 1,4, OR 6 BETWEEN RECTANGULAR AND FLAT-OVAL OR RADIUS CORNER COMPONENTS. SEE NOTE 8 FOR LIMITATIONS.






TYPE I TRANSFORMATION (SYMMETRICAL)


PREFERRED USAGE :

IN ALL CASES WHERE TRANSFORMATION IS REQUIRED BETWEEN RECTANGULAR COMPONENTS. SEE NOTE 8 FOR LIMITATIONS.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

	3128	MARAD CÒNIR	1009 Stawing No.	
	8	2-36233	4966-SK-006	
٧	BEAL	NONE	SHEET 9 00	31







TYPE & TRANSFORMATION (FLAT- SIDED)

PREFERRED USAGE!

IN ALL CASES WHERE TRANSFORMATION IS REQUIRED BETWEEN RECTANGULAR AND ROUND COMPONENTS AND SPACE AVAILABILITY REQUIRES THAT ONE SIDE BE KEPT FLAT.

SEE NOTE 8 FOR LIMITATIONS.







TYPE 5 TRANSFORMATION (FLAT-SIDED)

PREFERRED USAGE:

ONLY WHERE PRESSURE -DROP CONSIDERATIONS DO NOT ALLOW USE OF FLANGE TYPES 3, AND 1, 4, OR 6 BETWEEN RECTANGULAR AND FLAT-OVAL OR RADIUS CORNER COMPONENTS, IN COMBINATION WITH TYPE 4 TRANSFORMATION.
SEE NOTE 8 FOR LIMITATIONS.






TYPE 4 TRANSFORMATION

PREFERRED USAGE

IN ALL CASES WHERE TRANSFORMATION IS REQUIRED BETWEEN RECTANGULAR COMPONENTS AND SPACE AVAILABILITY REQUIRES THAT ONE SIDE BE KEPT FLAT.
SEE NOTE 8 FOR LIMITATIONS.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

Ì				
	5124	MARAD CONTE	TODD BRAWING NO.	401
	8	2-36233	4966-5K-006	
	15.00	NONE	snear2007	वा




TYPE 3 BRANCH TAKE-OFF


RECT BRANCH - FLARED
RECT MAIN (CONSTANT SIZE)
TAKE-OFF ANGLE = 90°

W2=1.5W1

L= .5WI (2.5"MIN)

SEE NOTE 9 FOR FURTHER INFO.







TYPE 2 BRANCH TAKE-OFF

RECT MAIN (CONSTANT SIZE)
TAKE-OFF ANGLE = 90°

SEE ROUND DUCT STANDARDS FOR DIMENSIONS C AND L.

SEE NOTE 9 FOR FURTHER INFO.






TYPE I BRANCH TAKE-OFF


RECT BRANCH
RECT MAIN (CONSTAIT SIZE)
TAKE-OFF ANGLE = 90°

SEE NOTE 9 FOR FURTHER INFO.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

	MARAD CONTE	TODO DEAWING NO.	***
-	2-36233	4966-SK-006	
SCALL	NONE	3 ME ET 21 00	31







TYPE & BRANCH TAKE-OFF

ROUND BRANCH RECT MAIN (CONSTANT SIZE) TAKE-OFF ANGLE =45°

SEE ROUND DUCT STANDARDS FOR DIMENSIONS C AND L.

SEE NOTE 9 FOR FURTHER INFO.






TYPE 5 BRANCH TAKE-OFF

RECT BRANCH RECT MAIN (CONSTANT SIZE) TAKE- OFF ANGLE = 45°

SEE NOTE 9 FOR FURTHER INFO:




TYPE 4 BRANCH TAKE-OFF
ROUND BRANCH (FLARED)
RECT MAIN (CONSTANT SIZE)
TAKE-OFF ANGLE = 90°

SEE ROUND DUCT STANDARDS FOR DIMENSIONS C,L, AND DIA 2.

SEE NOTE 9 FOR FURTHER INFO.


NATIONAL SHIPBUILDING RESEARCH PROGRAM
RECTANGULAR DUCT STANDARDS


2-36233 4966-SK-006



RECT BRANCH
RECT MAIN (TRANSFORMING)
TAKE-OFF ANGLE = 45°

SEE NOTE 9 FOR FURTHER INFO.






TYPE & BRANCH TAKE-OFF

ROUND BRANCH RECT MAIN (TRANSFORMING) TAKE-OFF ANGLE = 90°

SEE ROUND DUCT STANDARDS FOR DIMENSIONS C AND L.

SEE NOTE 9 FOR FURTHER INFO.




TYPE 7 BRANCH TAKE-OFF

RECT BRANCH RECT MAIN (TRANSFORMING) TAKE-OFF ANGLE = 90°

SEE NOTE 9 FOR FURTHER INFO.

NATIONAL SHIPBUILDING RESEARCH PROGRAM


8128		TODD BRAWING NO.	227
	2-36233	4966-SK-006	
SCALE	NONE	SHEET 2307 9	1




TYPE 2 TERMINAL - BELLMOUTH
DI AND WI = DUCT DIMENSIONS
D2 = DI + 2R W2 = W1 + 2R

CLEARANCE FOR ONE-INCH LIP REQUIRED ONLY FOR WIRE MESH INSTALLATION.

LARGEST OF DIMENSIONS DI-OR WI (INCHES)	R (INCHES)
2-8	
9-16	2
17-24	3
25-32	4
33-40	5
41-48	6
49-54	7







TYPE I TERMINAL - CONE

DI AND WI = DUCT DIMENSIONS.
D2 AND W2 = TERMINAL OPENING
DIMENSIONS (WHOLE INCHES
ONLY - NO FRACTIONS).

CLEARANCE FOR ONE-INCH LIP REQUIRED ONLY FOR WIRE MESH INSTALLATION.






TYPE 10 BRANCH TAKE-OFF:
ROUND BRANCH
RECT MAIN (TRANSFORMING)
TAKE-OFF ANGLE =45°


SEE ROUND DUCT STANDARDS FOR DIMENSIONS C AND L.

SEE NOTE 9 FOR FURTHER INFO.

IATIONAL	SHIPBUILDI	NG RES	EARCH	PROGRAM
RECT	ANGULAR	DUCT	STAND	AR DS

	3126	MARAD CONTE	1000 DIAWING NO.	
		2-36233	4966-5K-006	
v	SCALE	NONE	5 NE 8 7 2401	31







TYPE 3 TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON FLAT-OVAL OR RADIUS CORNER COAMINGS.

PREFERRED USAGE!

IN ALL CASES, UNLESS UNACCEPTABLE PRESSURE DROP LOSSES RESULT, USE OF THIS CONNECTION TYPE IS TO BE MAXIMIZED.






TYPE 2 TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON FLAT-OVAL OR RADIUS CORNER COMMINGS.

PREFERRED USAGE:

ONLY WHERE USE OF TYPE 3 FLANGE IS IMPRACTICAL DUE TO UNACCEPTABLE PRESSURE DROP LOSS. USE OF THIS CONNECTION TYPE IS TO BE MINIMIZED.



TYPE | TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON COMPONENTS MEETING CLASS 'A' FIRE PROTECTION REQUIREMENTS, AND ON WATERTIGHT COMPONENTS.


PREFERRED USAGE :

WITH TYPE 3 FLANGE WHEN CONNECTING TO FLAT-OWL OR RADIUS CORNER COMMINGS, AND FOR CONNECTING TO FLANGE TYPE 1,4, AND G.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

RECTANGULAR DUCT STANDARDS

2-36233 , 4966-SK-006





TYPE G TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON NON-WATERTIGHT COMPOJENTS NOT REQUIRED TO MEET CLASS 'A' FIRE PROTECTION REQUIREMENTS.

PREFERRED USAGE!

FOR CONNECTION TO EQUIPMENT AND TO FLANGE TYPES 1, 3, 4, AND G. NOT TO BE USED WHERE CONNECTED COMPONENTS WILL BE SUBJECT TO TENSILE STRESS DURING OR AFTER INSTALLATION, UTILIZATION OF THIS TYPE IS SHOP DECISION.






TYPE 5 TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON NON-WATERTIGHT COMPONENTS WITH RADIUS CORNERS NOT REQUIRED TO MEET CLASS 'A' FIRE PROTECTION REQUIREMENTS,

PREFERRED USAGE :

ONLY WHEN CONNECTING TO FLANGE TYPE 2. USE SHALL BE MINIMIZED IN FAVOR OF FLANGE TYPES 3, \$4 OR G, WHERE PRESSURE DROP CONSIDERATIONS ALLOW.






FOR INSTALLATION ON NON-WATERTIGHT COMPONENTS NOT REQUIRED TO MEET CLASS IN FIRE PROTECTION REQUIREMENTS.


PREFERRED USAGE:

FOR CONNECTION TO EQUIPMENT, AND TO FLANGE TYPES 1,3,4, AND 6.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

			- 1
\$128	MARAD CONIS	TORR BRAWING NO.	
-	2-36233	4966-5K-006	
BEALE	NONE	344426042	







TYPE S TRANSVERSE CONNECTION (NON-FLANGED, OVERLAP RIVETED)

FOR CONLECTION OF NON-WATERTIGHT COMPONENTS NOT REQUIRED TO MEET CLASS 'A' FIRE PROTECTION REQUIREMENTS.

PREFERRED USAGE:

WHERE USE OF FLANGE TYPES 4 OR G IS NOT NECESSARY, AND WHERE PORTABILITY IS NOT REQUIRED. CHOICE BETWEEN THIS TYPE AND TYPES 10,11, AND 12 IS SHOP DECISION







TYPE 8 TRANSVERSE CONNECTION (NON-FLANGED, WELDED)

FOR CONNECTION OF WATERTIGHT COMPONENTS, AND OF COMPONENTS MEETING CLASS & FIRE PROTECTION REQUIREMENTS.

PREFERRED USAGE: WHERE PORTABILITY IS NOT REQUIRED.





TYPE 7 TRANSVERSE CONNECTION (FLANGED TYPE)

FOR INSTALLATION ON NON-WATERTIGHT COMPONENTS WITH RADIUS CORNERS NOT REQUIRED TO MEET CLASS 'X' FIRE PROTECTION REGUIREMENTS.


REQUIREMENTS.


PREFERRED USAGE: ONLY WHEN CONNECTING TO FLANGE TYPE 2. NOT TO BE USED WHERE CONNECTED COMPONENTS WILL BE SUBJECT TO TENSILE STRESS DURING OR AFTER INSTALLATION.

UTILIZATION OF THIS TYPE IS SHOP DECISION.


NATIONAL SHIPBUILDING RESEARCH PROGRAM

8120	MARAD CONTA	TODS BRAWING NO.	
•	2-36233	4966-9K-006	
BEALL	NONE	SHEE1 2700	31






*HEE12801 91



COVER SIZE - DIM A & B (INCHES)	OPENING SIZE (INCHES)
5X7 FLAT-OVAL	4X6 FLAT-OVAL
7X9 FLAT-OVAL	GXB FLAT-OVAL



(BOLTED -WATERTIGHT AND NON-WATERTIGHT)

FOR INSTALLATION ON COMPONENTS WHERE TYPE 2 ACCESS COVER IS NOT DESIRED.


THE SMALLEST ACCESS HOLE DIMENSIONS (A AND B) ARE 4" X 6-1/2". THEREAFTER EITHER OR BOTH MAY BE INCREASED BY 2-1/2" INCREMENTS


RECOMMENDED SIZES (DIMENSIONS A AND B):

G-1/2" X G-1/2"

9" X 9"

14" X 14"





TYPE 12 TRANSVERSE CONNECTION (NON-FLANGED, LATCH TYPE-ALTERNATE)


EXCEPT FOR THE 'C' DIM ON THE STRIKE SIDE, AND CONFIGURATION OF THE RETAINING CLIP, ALL INFORMATION GIVEN FOR THE TYPE 12 (BASIC) CONNECTION IS TRUE FOR THIS TYPE.


PREFERRED USAGE:

MIERE USE OF FLANGE TYPES 4 OR G IS NOT NECESSARY CHOICE DETWEEN THIS TYPE AND TYPES 0,10,11, AND 12 (BASIC) IS SHOP DECISION. SEE NOTE 13 FOR LIMITATIONS.

NATIONAL SHIPBUILDING RESEARCH PROGRAM

\$124	MARAD CONTR	TODE BRAWING NO.	
•	2-36233	4966-5K-006	
SCALE	NONE	Sect 2901	1





APPENDIX B

SAMPLE CONSTRUCTION DRAWINGS

This appendix contains representative sheets from the Rectangular Duct Standards Construction and Fabrication Drawing. All information necessary for a sheet metal shop to fabricate the standard vent duct components is incorporated.


The complete Fabrication Drawing is available to U.S. shipbuilders from:


R&D Program Manager Todd Shipyards Corporation Seattle Division P. O. Box 3806 Seattle, WA 98124


To others, when cataloged, the Drawing may be obtained from:


National Technical Information Service 5285 Port Royal Road Springfield, VA 22161


Any proposals for significant modifications should be addressed to the Todd R&D Program Manager.














APPENDIX C

SAMPLE TABLES FOR MATERIAL QUANTITIES AND DIMENSIONS

Representative computer tabulations of material quantities and dimensions are contained in this Appendix. Also included is a sample of a computer program used to generate the tabulations.

Copies of the complete tabulations and/or programs are available to U.S. shipbuilders from:

R&D Program Manager Todd Shipyards Corporation Seattle Division P. O. Box 3806 Seattle, WA 98124

Or, when cataloged, from:

National Technical Information Service 5285 Port Royal Road Springfield, VA 22161

Any proposals for significant modifications should be addressed to the Todd R&D Program Manager.

NOTE: The economically advantageous standard sizes, each identified with an asterisk, are established in two-inch increments and should be used unless there is special reason to do otherwise. The information presented herein is in one-inch increments only to accommodate special needs.

INDEX										
PAGE CON	rents									
988-1013 TRANSVE	o (TYPES 1,2, (TYPES 1 \$2 COVERS (TYI RSE CONNEC ES 1,2,3,4,5, RSE CONNECT S 9,10,11,12B	.) PE 1-8 TIONS- 6,47) IONS-I ASIC.4	FLAN FLAN NON F	IGED FLAN ERNA	GED KTE)					
1014 - 1065 - MIKE ME	ON SCHEEM	wat C. C.		161-11	.,	,		REFERE	NCES	
1 ()							NO.	TITLE		TODD DWG NO.
·						:	I RI	CTANGULAR DU	CT STANDARDS	
							-0	ONSTRUCTION	AND FABRICATION	
							2 RE	CTANGULAR DU	CT STANDARDS	
							-1	DESIGNERS PA	MPHLET	
							十	<u> </u>	***************************************	
							NAT	IONAL SHIPBU	ILDING RESEARC	CH PROGRAM
	APPROVAL					DATE			LAR DUCT STA	
	USCG						DIME	ENSIONAL CRITE	RIA AND MATERIA RECTANGULAR DU	L QUANTITIES CT STANDARDS
	ABS		 			•	'N.	- CONSTRUCT	ION AND FABRIC	LATION
' '	PHS	····			1		1			
							SIZE	MARAD CONTR	TODD DRAWING	NO.
		÷					_	2-36233	4966-	sK-008
		TT		T	7	REV	SCALE		SHEET \$ 106	2 DOTA SHEETS
<u> </u>						1	L			

			Alght DUCT Tandard Size)
	D DIM	W DIM	MATERIAL REQUIRED PER ONE LINEAR FOOT (SQ FT)**
*	2	4	1.00
	2	5	1.17
	2	6	1.33
	2	7	1.50
•	2	8	1.67
	3	4	1.17
	3	5	1.33
	3	6	1.50
	3	7	1.67
	3	8	1.63
	3	9	2.00
	3	10	2.17
	3	11	2.33
•	4	4	1.33
	4	5	1.50
*	4	6	1.67
	4	7	1.03
•	4	8	2.00

** - MATERIAL IS NET AND DOES NOT INCLUDE ALLOMANCE FOR LONGITUDINAL CORNER SEAMS. IF THESE ARE PRESENT, ADD .15 SQ FT PER LINEAR FOOT FOR EACH SUCH SEAM.

			AIGHT DUCT TANDARD SIZE)
	MIG C	W DIM	MATERIAL REQUIRED PER ONE LINEAR FOOT (SQ FT)++
	4	9	2.17
•	4	10	2.33
	4	11	2.50
•	4	12	2.67
	4	13	2.83
•	4	14	3.00
	5	5	1.67
	5	6	1.83
	5	7	2.00
	5	8	2.17
	5	9	2.33
	5	10	2.50
	5	11	2.67
	5	12	2.03
	5	13	3.00
	5	14	3.17
	5	15	3.33
•	6	6	2.00

ELBOWS - TYPES 1, 2, 3, AND 4

		TYPE 1 ELBOW							71	/PE 2 (LBOW			TY	PE 3 EI	FBOM		TYPE 4 ELBOW		
(IN)	H (1N)	ANGLE (DEG)		TL (1N)	HR (IN)	HL (IN)	AREA (SQ FT)	TR (IN)	TL (IN)	HR (1N)	HL (TM)	AREA (SQ FT)	TR (1N)	TL (IN)	HR (IN)	HL (EN)	AREA (SQ FT)	HL (IN)	AREA (SQ FT)	
* 2	, 4	15	4.0	1- 1	8.0	2- 4	0.21	2.0	0-16	6.0	1-19	0.14	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	
		30	4.0	2- 2	8.0	4- 7	0.42	2.0	1- 1	6.0	3- 6	0.28	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	
		45	4.0	3- 4	8.0	6-11	0.62	2.0	1-17	6.0	4-24	0.42	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	
		60	4.0	4- 5	8.0	8-14	0.83	2.0	2- 2	6.0	6-11	0.55	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	
		75	4.0	5- 6	8.0	10-18	1.04	2.0	2-18	6.0	7-30	0.69	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	
		90	4.0	6- 7	8.0	12-21	1.25	2.0	3- 3	6.0	9-17	0.83	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	

SPLITTER AND VANE DATA

ţ			PE 2 ELE D SPLITT						TYPE 4 ELBOW (VANES)					
ANGLE (DEG)	S1 (IN)	SL1 (IN)	\$2 (IN)	(IN)	AREA (SQ FT)	S1 (IN)	SL1 (1N)	\$2 (1N)	SL2 (1N)	S3 (IN)	SL3 (IN)	AREA (SQ FT)	NO. REQD	AREA (SQ FT)
15	0.0	0- 0	0.0	0- 0	0.0	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	0.0
30	3.00	1-19	4.25	2- 8	0.05	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	0.0
45	3.00	2-12	4.25	3-12	0.08	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	0.0
60	3.00	3- 6	4.25	4-15	0.11	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	/ 0.0
75	3.00	3-31	4.25	5-19	0.13	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	0.0
90	3.00	4-24	4.25	6-23	0.16	0.0	0- 0	0.0	0- 0	0.0	0- 0	0.0	0	0.0

- NOTES 1- *=STAMDARD SIZE.
 2- DIMENSIONAL NOMENCLATURE AGREES WITH THAT USED IN RECTANGULAR DUCT STANDARDS (CONSTRUCTION AND FABRICATION).
 3- AREAS (NET MATERIAL REQD TO FABRICATE COMPONENT) FOR TYPES 1,2,3,AND 4 ELBOMS ASSUME PITTSBURGH TYPE LONGITUDINAL

 - CORNER SEARS.

 4- SPLITTER AREAS INCLUDE HEM MATERIAL, MHERE APPLICABLE.

 5- ZERO ENTRIES INDICATE NON-AVAILABILITY OF THE FITTING IN THAT SIZE OR ANGLE.

 6- ALL COMPONENT LENGTHS (TL.HL,SL1,SL2,SL3) ARE GIVEN IN WHOLE INCHES AND 32NDS OF AN INCH. FOR EXAMPLE, A LENGTH GIVEN AS 6-5 MOULD BE 6 AND 5/32 INCHES LONG.

OFFSETS - TYPES 1 AND 2

			TYP	E 1 0	FFSET	ITR= 2.	0, HR=	4.01	TYP	E 2 0	FFSET	(TR= 0.	.O, HR=	0.0)	SPLITTE	R DATA	FOR TYPE	2 OFFSET
	(1N)	(A1)	ANGLE (CEG)		H1 (IN)	(IN)	UL (IN)	WL (IN)	ANGLE (DEG)	(IN)	HI (IN)	(IN)	(IN)	(IN)	\$1 (1N)	SL1 (IN)	\$2 (1N)	(IN)
,	2	1	33.6	3	5	3-10	1- 5	3-17	c.0	0	0	0- 0	0- 0	C- C	0.0	0- 0	C.0	e- o
		2	48.2	4	4	4-15	1-21	5- 2	c.0	0	0	0- 0	0- 0	0- 0	0.0	0- 0	G.0	0- 0
		3	60.0	5	3	5- 6	2- 2	6-1C	0.0	0	C	c- o	0- 0	0- 0	0.0	0- 0	C.O.	0- 0
		4	70.5	6	2	5-21	2-14	7-14	0.0	0	C	0- 0	0- 0	0- 0	0.0	0- 0	C.0	0- 0
		5	80.4	7	1	5-29	2-24	8-15	c.0	0	C	G- 0	0- 0	0- 0	0.0	0- 0	C.0	0- 0
		6	92.0	8	Q	6- 0	3- 3	9-15	c.0	0	e	0- 0	0- 0	0- 0	0.0	0- O	C.0	C- 0

1 ,

NOTES 1- *=STANCARD W DIMENSION.
2- CIMENSICHAL NOMENCLATURE AGREES WITH THAT USED IN RECTANGULAR DUCT STANDARDS (CONSTRUCTION AND FABRICATION).
3- ZERC FMTRIES INDICATE NOM-AVAILABILITY OF THE FITTING IN THAT SIZE OR ANGLE.
4- ALL COPPONENT LENGTHS (L,UL,NL,SL).SL2) ARE GIVEN IN WHOLE INCHES AND 32ADS OF AN INCH. FOR EXAMPLE, A LENGTH GIVEN AS 6-5 WOULD BE 6 AND 5/32 INCHES LYNG.
5- MHERE THE LARGEST ANGLE INDICATED IS LESS THAN 90 DEGREES, THE CORRESPONDING OFFSET CHEEK IS THE LARGEST THAT CAN BE CUT (IN ONE PIECE) FROM A 4-FOOT BY 8-FOOT SHEET METAL BLANK.
6- AREAS (PATERIAL REQUIREMENTS) FOR OFFSETS AND SPLITTERS RAY BE DETERMINED BY COUBLING THE AREA DATA GIVEN FOR 90 CECREE ELBOWS OF THE SAME D.M.AND TR DIPENSIONS (FOUND ON PAGES 13-813), MULTIPLYING THAT QUANTITY BY THE ACTUAL CFFSFT ANGLE INDICATED ABOVE, AND DIVIDING THE RESULT BY 90.

ACCESS COVERS - TYPE 1 - BOLTED

CPENING (A)	DIMENSIONS B. (IN)	COVER A+2 (1N)	CIMENSIONS 8+2 (IN)	COVER MATERIAL REQUIREMENTS (SQ FT)	FASTENER QUANTITY (SETS)	GASKET MATERIAL REQUIREMENTS (LINEAR FEET)	FRAME MATERIAL REQUIREMENTS (LINEAR FEET)
				4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4			
4.0	6.5	6.0	8.5	0.4	10	2.1	2.1
4.0	9.0	6.0	11.0	0.5	12	2.5	2.5
4.0	11.5	6.0	13.5	0.6	14	2.9	2.9
6.5	6.5	8.5	8.5	0.5	12	2.5	2.5
6.5	9.0	8.5	11.0	0.6	14	2.9	2.9
	11.5	8.5	13.5	0.8	16	3.3	3.3
6.5		8.5	16.0	0.9	18	3.8	3.8
6.5	14.0			1.1	20	4.2	4.2
6.5;	16.5	8.5			22	4.6	4.6
6.5	19.0	8.5	21.0	1.2			3.3
9.0	9.0	11.0	11.0	C-8	16	3.3	
5.0	11.5	11.0	13.5	1.0	18	3.8	3.8
9.C	14.0	11.0	16.0	1.2	20	4.2	4.2
7.0	16.5	11.0	18.5	1.4	22	4.6	4.6
9.0	19.0	11.0		1.6	24	5.0	5.0
		11.0		1.8	26	5.4	5.4
9.C	21.5			2.0	28	5.8	5.8
9.0	24.0	11.0	26.0	2.0	20		

NCTES
1- DIMENSIONAL NOMENCLATURE AGREES WITH THAT USED IN REGTANGULAR DUCT STANDARDS (COMSTRUCTION AND FABRICATION).
2- EACH FASTENER SET INCLUDES ONE (1) MACHINE SCREW, AND ONE (1) CAPTIVE FASTENER.
3- FRAME MATERIAL INDICATED ANOVE IS REQUIRED ONLY FOR THE NON-TIGHT AND AIR-TIGHT ACCESS COVER (ALTH 1),
AS SHOWN IN THE CONSTRUCTION AND FABRICATION DETAILS.
4- GASKET MATERIAL INCICATED ABOVE ASSUMES GASKET CUT FROM 1-INCH WIDE STRIPS, AND PROPERLY SEALED AT MATING EDGES.

TRANSVERSE CONNECTIONS - FLANGED (TYPES 1,2,3,4,5,6,AND 7)

											****					•
						FLAN	GE MATERI	AL			FASTE			VETS	GASKET N	ATERIAL
	D (1N)	(IN)	RC (IN)	TYPE 1 (LIN FT)	TYPE (SQ FT)	TYPE 3 (SQ FT)	TYPE (LIN FT)	TYPE 5	TYPE 6 (LIN FT)	TYPE 7 (SQ FT)	TYPES 1,3,4,6 (SETS)	TYPES 2,5,7 (SETS)	TYPE (QTY)	TYPE 5 (QTY)	TYPES 1,3,4,6 (LIN FT)	TYPES 2,5,7 (SQ FT)
	2	4	1	1.6	0.2	0.2	1.5	1.1	1.5	0.2	8	6	6	5	1.5	0.1
	2	5	1	1.8	0.2	0.2	1.7	1.3	1.7	0.2	8	6	. 6	6	1.7	0.2
•	2	6	1	1.9	0.2	0.2	1.9	1.4	1.9	0.2	10	8	. 8	7	1.9	9.2
	2	7	1	2.1	0.2	0.3	2.0	1.6	2.0	0.2	10	8	8		2.0	0.2
•	2	8	1	2.3	0.2	3.3	2.2	1.6	2.2	0.2	12	8	10	9	2.2	0.2
	3	4	1	1.6	0.2	0-2	1.7	1.3	1.7	0.2	8	6	6	6	1.7	G.2
	3	5	1	1.9	0.2	0.2	1.9	1.4	1.9	0.2	8	6	6	7	1.9	0.2
	3	6	1	2.1	0.2	0.3	2.0	1.6	2.0	0.2	10	8	. 8	8	2.0	0.2
	3	7	1	2.3	0.2	0.3	2.2	1.0	2.2	0.2	10	8	8	9	2.2	6.2
	3	8	1	2.4	0.3	7.3	2.4	1.9	2.4	0.3	12	8	16	10	2.4	0.2
	3	9	1	2.6	0.3	0.3	2.5	7.1	2.5	0.3	12		13	11	2.5	0.3
	3	10	1	2.8	0.3	3.4	2.7	7.3	2.7	0.3	12	10	12	12	2.7	0.3
	3	11	1	2.9	0.3	0.4	2.9	7.4	2.9	0.3	12	10	12	13	2.9	0.3
	4	4	1	1.9	0.2	0.2	1.9	1.4	1.9	0.2		8	8	7	1.9	0.2

- NOTES 1- *=STANDARD SIZE.
 2- DIMENSIONAL NOMENCLATURE AGREES WITH THAT USED IN RECTANGULAR DUCT STANDARDS (CONSTRUCTION AND FABRICATION).
 - 3- FLANGE NATERIAL AND RIVETS AS GIVEN ABOVE IS THAT MATERIAL REQUIRED TO FABRICATE ONE SIDE OF THE TOTAL CONNECTION. (ONE COMPLETE TYPE).

 - (ONE COMPLETE TYPE).

 4- FASTENERS AND GASKET MATERIAL AS GIVEN ABOVE IS THAT MATERIAL REQUIRED FOR THE TOTAL CONNECTION (CHE TYPE MATED TO ANOTHER TYPE). EACH FASTENER SET INCLUDES ONE (1) MACHINE SCREW, AND ONE (1) NUT. GASKET MATERIAL FOR TYPES 1.3.4. AND 4 ASSUMES GASKET CUT FROM 1-3/0 INCH MIDE STRIPS, AND PROPERLY SEALED AT MATING EDGES.

 5- RC VALUES AS GIVEN ABOVE ARE THOSE RADIUS CORNER DIMENSIONS RECOMMENDED FOR THE CORRESPONDING OUCT SIZE. AND ARE IN AGREEMENT WITH THOSE VALUES INDICATED IN RECTANGULAR DUCT STANDARDS (DESIGNERS PARMHLET). THE RC VALUES APPLY ONLY TO TYPES 2.3.5.AND 7. WHERE RC VALUES DIFFER FROM THOSE GIVEN, THE REQUIRED FASTENER QUANTITIES MAY BE CALCULATED FROM THE BOLT LOCATION DATA GIVEN IN THE CONSTRUCTION AND FABRICATION DETAILS. (HOWEVER, FOR THESE CASES, ALL INFORMATION AS GIVEN ABOVE MAY BE USED FOR MATERIAL ESTIMATING, MITHOUT APPRECIABLE ERROR.)

TRANSVERSE CONNECTIONS - NON FLANGED (TYPES 9,10,11,128ASIC, AND 12ALTERNATE)

٠											•				
			TYPE 9	TYPE	10		TYPE				PE 128451	-	TYPE	12ALTERNA	TE
	(1N)	(IN)	RIVETS (QTY)	DRIVE-SLI		DRIVE-SLI		S-CI (LIN FT)		RETAININ (LIN PT)		RIVETS (QTY)	RETAIN!	G CLIPS (SQ FT)	RIVETS (QTY)
•	2	4	6	1.4	0.2	0.7	0.1	0.6	. 0.2	1.0	0.2	6	1.0	0.3	6
	2	5	6	1.5	0.3	0.7	0.1	0.8	0.2	1.1	0.2	10	1.1	0.3	6
•	2	6	8	1.7	0.3	0.7	0.1	1.0	0.3	1.3	0.2	10	1.3	0.4	6
	2	7		1.9	0.3	0.7	0.1	1.1	0.3	1.5	0.3	10	1.5	0.4	6
٠	2	8	10	2.0	0.4	0.7	0.1	1.3	0.4	1.6	0.3	10	1.6	0.5	6
	3	4	6	1.5	0.3	0.8	0.2	0.6	0.2	1.1	0.2	6	1.1	0.3	6
	3	5 '	6	1.7	0.3	0.8	0.2	0.8	0.2	1.3	0.2	10	1.3	0.4	6
	3	, 6	8	1.9	0.3	0.8	0.2	1.0	0.3	1.5	0.3	10	1.5	0.4	6
	3	. 1	8	2.0	0.4	0.6	0.2	1.1	0.3	1.6	0.3	10	1.6	0.5	6
	3	8	10	2.2	0.4	0.6	0.2	1.3	0.4	1.8	0.3	10	1.6	0.5	6
	3	9	10	2.4	0.4	0.8	0.2	1.5	0.4	2.0	0.4	10	2.0	0.6	6
	3	10	12	2.5	0.5	0.8	0.2	1.6	. 0.4	2.1	0.4	14	2.1	0.6	10
	3	11	12	2.7	0.5	0.8	0.2	1.6	0.5	2.3	0.4	14	2.3	0.7	10
•	4	4	8	1.7	0.3	1.0	0.2	0.6	0.2	1.3	0.2	8	1.3	0.4	6
	4	5	8	1.9	0.3	1.0	0.2	0.8	0.2	1.5	0.3	12	1.5	0.4	6
•	4	6	10	2.0	0.4	1.0	0.2	1.0	0.3	1.6	0.3	12	1.6	0.5	6

NOTES 1- #-STANDARD SIZE.
2- DIMENSIONAL NOMENCLATURE AGREES WITH THAT USED IN RECTANGULAR DUCT STANDARDS (CONSTRUCTION AND FABRICATION).
3- ZERO ENTRIES INDICATE NON-AVAILABILITY OF CONNECTION TYPE IN THAT SIZE.
4- MATERIAL AS INDICATED ABOVE IS THAT MATERIAL REQUIRED TO FABRICATE THE TOTAL CONNECTION.
5- THE MATERIAL QUANTITY LISTED IN THE SQ FT COLUMN FOR TYPE 11 S-CLIPS IS THAT MATERIAL REQUIRED FOR THE S-CLIP WITHOUT REINFORCING LEG. IF REINFORCING LEGS ARE REQUIRED, ADD .2 SQ FT TO THE QUANTITY SHOWN FOR EACH LINEAR FOOT OF S-CLIP.

WIRE MESH SCREENING (TYPES 1,2,3,4,AND 5)

														•	
CPN	G DIM	T	YPES 1 A	MD 4		TYPE 2			TYPE 3				TYPE	5	
(IN)	(11)	FRAME (LIN FT)	SCREEN (SO FT)	FASTENERS (SETS)	FRAME (LIN FT)	SCREEN (SQ FT)	FASTEMERS (SETS)	FRAPE (LIN FT)	SCREEN (SQ FT)	FASTENERS (SETS)	RC	FRAME (LIN FT)	SCREEN (SQ FT)	FASTEN EXP	ERS (SETS) NOT EXP
2	4	1.3	Ů.1	2	6.3	C.0	0	0.0	0.0	0	0	0.0	0.0		0
2	5	1.5	0.2	2	1.5	0.2	2	0.0	0.0	0	0	0.0	0.0		•
2	6	1.7	9.2	4	1.7	0.2	4	0.0	0.0	0	0	0.0	0.0	0	0
2	7	1.8	0.2	4	1.8	0.2	4	0.0	0.0	0	0	0.0	0.0	٥	0
2	A	2.C	0.3	4	2.0	0.3	4	0.0	0.0	0	0	0.0	0.0	0	G
3	4	1.5	0.2	4	1.5	0.2	4	. 0.0	0.0	G	1	0.8	0.1	4	4
3	5	1.7	0.2	4	1.7	9.2	4	0.0	0.0	0	1	1.0	0.2	4	·
3	6	1.8	0.3	6	1.8	0.3	- 6	0.0	0.0	0	1	1.1	0.2		•
3	7	2.C	≎.3	6	2.0	0.3	6	0.0	0.0	0	1	1.3	0.2	4	· A
3	8	2.2	0.3	6	2.2	0.3	6	0.0	0.0	e	1	1.5	0.3	, ,	4
3	9	2.3	0.4	6	2.3	0.4	6	0.0	0.0	0	1	1.6	0.3	6	7
3	10	2.5	0.4	6	2.5	0.4	6	0.0	0.0	0	1	1.8	0.3		
.3	11	2.7	C.4	6	2.7	0.4	6	0.0	0.0	0	1	2.0	0.3		
4	4	1.7	0.2	4	1.7	0.2	4	0.0	0.0	C	1	1.0	0.2	17.	
4	5	1.8	0.3	4	1.0	0.3	4	0.0	0.0	0	ı	1.1	0.2	4	4

NOTES

1 DIMENSIONAL NOMENCLATURE AGREES WITH THAT USED IN RECTANGULAR DUCT STANDARDS (CONSTRUCTION AND FABRICATION).

2 ZERC ENTRIES INDICATE NON-AVAILABILITY OF FITTING TYPE IN THAT SIZE.

3 EACH FASTENER SET INCLUDES DNE (1) HACHINF SCREW, AND ONE (1) HUT OR CAPTIVE FASTENER.

4 FRAPE PATERIAL FOR ALL TYPES ASSUMES FRAME CUT FROM 2-INCH MIDE STRIPS.

5 RC VALUES AS GIVEN ABOVE ARE THOSE RADIUS CORNER DIMENSIONS RECOMMENDED FOR THE CORRESPONDING OPENING DIMENSIONS, APPLY GNLY TO TYPE 5. WHERE RC VALUES DIFFER FROM THOSE GIVEN, THE REQUIRED FASTENER QUANTITIES HAV BE CALCULATED FROM THE BOLT LOCATION DATA GIVEN IN THE CONSTRUCTION AND FABRICATION DETAILS. (HOWEVER, FOR THESE CASES, ALL 6- SCREEN NATERIAL AS GIVEN ABOVE IS BASED ON CROSS-SECTIONAL DIMENSIONS OF (0-1.75)X(M+1.75), FOR TYPES 1.2,3,AND 4, CONSTRUCTION AND FABRICATION AND FABRICATION AS GIVEN IN THE

```
DOS FORTRAN IV 360N-FO-479 3-6
                                            MAINPGM
                                                                 DATE 04/05/76
                                                                                        TIME
                                                                                                18.09.41
                                                                                                                 PAGE 0001
                     REAL DI.WI.A
 0001
                      INTEGER D.W.C.C1.SSD.SSW.X.WAX.TOP
 0002
 0003
                     TOP=0
 0004
                     SSD=1
 0005
                     SSH=1
 0006
                     X=0
                     C1=0
 0007
 0008
                     C=1
 0009
                     D=2
 0010
                     W=O
 0011
                     01=0.
 0012
                     W1=0.
 0013
                     UHAX=0
                   1 IF(D.EQ.2)GO TO 2
IF(D.EQ.3)GO TO 3
 0014
 0015
                     IFID.EQ.43GO TO 4
IFID.LT.191GO TO 5
 0016
 0017
                     IFID.EQ.19)GO TO 6
 0018
                     WMAX=24
0019
0020
                   7 W=D
                   8 D1=D
 0021
 0022
                     WI=W
                   9 IFITOP.EQ.OIGO TO 10
 0023
 0024
                     GO TO 11
 0025
                   2 WHAX=8
 0026
                  12 W=4
                     GO TO 8
 0027
                   3 WMAX=11
 0028
 0029
                     GO TO 12
 0030
                   4 WMAX=14
 0031
                     GO TO 7
 0032
                   5 WMAX=3+D
 0033
                     GO TO 7
 0034
                   6 WMAX=54
0035
                     GO TO 7
                  10 WRITE(3,112)
 0036
                 112 FORMAT(//////26x,13MSTRAIGHT DUCT/23x,19H(* = STANDARD SIZE)//31
1x,17MMATERIAL REGUIRED/16x,5MD DIM.2X,5MW DIM.2X,19MPER ONE LINEAR
 0037
                    2 FOOT/17X,4H(IN),3X,4H(IN),8X,9H(SO FT)++)
                     TOP=1
 0038
                  11 A=101+H1)/6.
1F([SSD.EQ.1].AND.(SSW.EQ.1))GO TJ 13
 0039
 0040
                  WRITE(3,14)D, M,A
14 FORMAT(/18X,12,5X,12,10X,F5.2)
GO TO 15
 0041
 0042
 0043
                  13 WRITE(3,16)D, N,A
 0044
 0045
                  16 FORMATI/12x, 1H+, 5x, 12, 5x, 12, 10x, F5.21
 0046
                  15 C1=C1+1
 0047
                      IF(D.EQ.24)GO TO 17
                     IFIC1.EQ.18160 TO 18
 0048
                  27 IFIW.EQ.WMAXIGO TO 19
 0049
 0050
                     H=W+1
 0051
                     W1=W
                     IF(SSW.EQ.1)GO TO 20
 0052
```

```
18.09.41
                                                                                                                                       PAGE 0002
                                                                              DATE 04/05/76
                                                                                                         TIME
DOS FORTRAN IV 360N-FO-479 3-6
                                                     MAINPGM
                          SSW=1
GO TO 9
 0053
 0054
                     27 SSN=0
GO TO 9
 0055
 0056
0057
                      19 D=D+1
                          1F(SSD.EQ.1)GO TO 21
 0058
                          SSD-1
 0059
 0060
                          SSW=1
                          60 TO 1
                      21 550-0
 0062
                      GO TO 1
17 IFIC.EQ.11GO TO 22
 0063
 0064
 0065
                          GO TO 100
                      22 X=1
  0066
                          GD TO 23
  0067
                      18 IFIC.EQ.1160 TO 24
 0068
                         C=1
                      29 WRITE(3,25)
25 FORMAT(1H1/)
  0070
  0071
 0072
0073
                          C1=0
                          IF(X.EQ.0)GD TD 26
                      60 TO 100
26 TOP=0
  0074
  0075
                          GO TO 27
  0076
                      24 C=0
 0077
0078
                      23 WRITE(3,28)
                      23 MRIIELS/20/
26 FORMATI/2X,55H00 - MATERIAL IS NET AND DOES NOT INCLUDE ALLOMANCE
1FOR/7X,48HLONGITUDINAL CORNER SEAMS. IF THESE ARE PRESENT,/7X,49HA
2DD .15 SQ FT PER LIMEAR FOOT FOR EACH SUCH SEAM.)
  0079
                    GO TO 29
101 CALL EXIT
END
  0080
  0081
  0082
```

APPENDIX D

RESEARCHER'S UNDERSTANDING OF SHIPBUILDING FUNCTIONS

This appendix contains a functional breakdown of the tasks necessary to design. produce, install and test a typical shipboard HVAC system. All cost figures are in February 1976 dollars. Careful analysis of the work-flow described in this Appendix will reveal the specific areas that are impacted upon by the Rectangular Vent Duct Standards.




Figure D-I

GENERAL CRITERIA

- The numbers shown in Figure D-1 are component identification numbers. Figure
 D-1 does not represent a typical system presently installed on any marine design.
 Its purpose is to portray many of the various rectangular type components which
 preliminary investigation indicates may benefit from standardization in respect
 to size, fabrication techniques, materials used, etc.
- Unless otherwise stated in the component description, all items are of nonwatertight construction.
- Various existing methods of component fabrication have been indicated for purposes of comparison with developed standards.
- All non-welded seams and joints have been assumed sealed after fabrication with an approved joint sealer.
- 5. Standard flanges Types 1, 2 and 3 are used.
- Unless otherwise noted, all steel has been assumed to be of the hot-dipped galvanized type, either before or after fabrication.
- Unless otherwise noted, all bolts, nuts, washers, etc., have been assumed to be of the cadmium plated steel type.
- Thermal insulation is 1" thick, cemented to the duct exterior, and covered with lagging cloth and vapor barrier.
- Acoustic insulation is I" thick, cemented to the duct interior, with the corners sealed with glass tape.
- Bolting of all flanges has been assumed to be accomplished during the installation procedure.
- Eighty percent of all transverse lap seam riveting has been assumed to be accomplished during the fabrication process, and twenty percent during installation.

- 12. Work associated with the welding of spools to ships structure has not been included since this is normally the function of specialized welding personnel.
- Forthe purpose of this tudy, "Indirect Cost" includes: clerical work, drafting supplies, plan reproduction, record keeping, plan file update, and other general and administrative expenses.
- 14. All material costs incurred by work task 2 & 3 have been included in work task 2.

COMPONENT IDENTIFICATION LIST

Item No. Description 1. Straight duct - 26" x 18", 36" long, with one type 2 flange. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams. 2. Duct hangers, 1½" x 3/16" steel F.B., 20 required of varying lengths. 3. Bolted access plate for 12" x 21" opening, 16 ga sheet steel, with gasket and I" x 1/8" framing ring. Auto/Manual fire damper, 26" x 18", 21" long, 1/8" thick steel casing. 4. with two type I flanges. Transformation piece, 26" x 18" - 26" x 18", 7" R.C., 6" long, 1/8" thick 5. steel, with two type I flanges, and two welded seams. Spool, 26" x 18", 7" R.C., 6" long, 1/4" thick steel, with two type I 6. flanges, and two welded seams. Same as item No. 5. 7.

- Remote operator (thru-bulkhead) for item No. 4, 1/8" thick steel casing, with two type 1 flanges, 14" long.
- Straight duct. 26" x 18", 51" long, with one type 2 flange and one lap riveted seam with item 10. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams.
- 10. Transformation piece, 26" x 18" 29" x 16", 9" long, 18 ga sheet steel, with two lap riveted seams for connection to items 9 & 11. Constructed with four "Pittsburgh" type seams.
- Straight duct, 29" x 16", 15" long, with one type 2 flange and one lap riveted seam with item 10. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams.
- Access plate for 12" dia opening, 1/8" thick steel, with gasket and 16 ga sheet steel framing ring.
- Flexible connection, 29" x 16", 5" long. Constructed of 1½" x 1½"
- 14. Same as item No. 12.
- 15. Straight duct, 29" x 16", 15" long, with one type 2 flange, and one lap riveted seam with items 16 & 34. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams.
- 16. Elbow, 17" x 16", 45°, 17" throat radius, with one type 3 flange and one lap riveted seam with item 15. Constructed of 20 ga sheet steel with four "Pittsburgh" type seams.
- 17. Straight duct, 17" x 16", 30" long, with one type 3 flange and one lap riveted seam with items 18 & 40. Constructed of 20 ga sheet steel with one welded seam.
- Straight duct, 9" x 16", 14" long, with two lap riveted seams with items
 4 19. Constructed of 20 ga sheet steel with one welded seam.
- 19. Transformation piece, 9" x 16" 18" x 9", 18" long, 20 ga sheet steel, with one type 3 flange and one lap riveted seam with item 18. Constructed with two welded seams.

- 20. Elbow, 18" x 9", 45°, 4½" throat radius, three splitters, one type 3 flange, and one lap riveted seam with item 21. Constructed of 20 ga sheet steel with four welded seams.
- Straight duct, 18" x 9", 10" long, with one type 2 flange and one lap riveted seam with item 20. Constructed of 20 ga sheet steel with one welded seam.
- 22. Manual fire damper, 18" x 9", 12" long, 1/8" thick steel casing, with two type 1 flanges.
- 23. Transformation piece, 18" x 9" 18" x 9" F.O., 6" long. 1/8" thick steel, with two type 1 flanges, and two welded seams.
- 24. Spool, 18" x 9" F.O., 6" long, 1/4" thick steel, with two type I flanges, and two welded seams.
- 25. Transformation piece, 18" x 9" F.O. 18" x 9", 6" long. 20 ga sheet steel with one type 2 flange, and one lap riveted seam with items 26 & 43. Constructed with two lap riveted seams.
- 26. Straight duct, 151/2" x 9", 15" long, with one type 2 flange, and one lap riveted seam with item 25. Constructed of 20 ga sheet steel with one welded seam.
- 27. Duct drain and sump. 15½" x 9", 24" long, 1/8" thick steel with two type 1 flunges.
- 28. Straight duct 151/2" x 9", 36" long, with one type 2 flange. Constructed of 20 ga sheet steel with two "Pittsburgh" type seams.
- 29. Straight duct 6" x 10", 9" long, with two lap riveted seams with items 9 & 30. Constructed of 22 ga sheet steel, with one "Pittsburgh" type seam. Used for 45° tap connection to main.
- 30. Elbow, 6" x 10", 45°, 6" throat radius, with one type 3 flange and one lap riveted seam with item 29. Constructed of 22 ga sheet steel, with four "Pittsburgh" type seams.
- Straight duct, 6" x 10", 24" long, with one type 3 flange and one lap riveted seam with item 33. Constructed of 22 ga sheet steel, with one grooved seam.

32.	Shut-off damper for 6" x 10" duct, 16 ga sheet steel, with operating gear.
-----	--

- 33. "J" terminal, 6" x 10" 7½" x 12", 7½" long, with one lap riveted seam with item 31. Constructed of 22 ga sheet steel with one lap riveted seam.
- 34. Elbow, 12" x 16", 90°, 6" throat radius, two splitters, and two lap riveted seams with items 15 & 35. Constructed of 20 ga sheet steel with four "Pittsburgh" type seams.
- 35. Straight duct 12" x 16", 36" long, with two lap riveted seams with items 34 & 67. Constructed of 20 ga sheet steel with two "Pittsburgh" type seams.
- Collar plate for 12" x 16" duct, two piece, 22 ga sheet steel, fastened to bulkhead with ¼" machine screws and nuts.
- Shut-off damper for 12" x 16" duct, 16 ga sheet steel, with operating gear.
- 38. Opening, side of duct, 18" x 10", with ½" x ½" screening and retaining ring.
- Splitter damper for 16" deep duct, 16 ga sheet steel, 8" long, with operating gear.
- Elbow, 8" x 16", 135°, 4" throat radius, and two lap riveted seams with items 17 & 41. Constructed of 20 ga sheet steel with four "Pittsburgh" type seams.
- Straight duct, 8" x 16", 22" long, with one type 3 flange, and one lap riveted seam with item 40. Constructed of 20 ga sheet steel with one welded seam.
- 42. Opening, end of duct, 8" x 16", with ½" x ½" screening and retaining ring.
- 43. Elbow, 2½" x 9". 90°, 2½" throat radius, and two lap riveted seams with items 25 & 44. Constructed of 22 ga sheet steel with four weight seams.
- 44. Transformation piece, 2½" x 9" 5" x 5", 6" long, 22 ga sheet steel with two lap riveted seams with items 43 & 45, and two welded seams.

- 45. Straight duct, 5" x 5", 36" long, with one type 3 flange and one lap riveted seam with item 44. Constructed of 24 ga sheet steel with one grooved seam.
- Balancing damper for 5" x 5" duct, 16 ga sheet steel, with operating gear.
- 47. "JA" terminal. 5" x 5" 6" x 6", 6" long, with one lap riveted seam with item 58. Constructed of 24 ga sheet steel with one lap riveted seam, and 1/2" x 1/2" screening and retaining ring.
- 48. Straight duct, thermally insulated, 20" x 10", 36" long, with one lap riveted seam with item 49. Constructed of 18 ga sheet steel, with two "Pittsburgh" type seams.
- 49. Transformation piece, thermally insulated, 20" x 10" 20" x 10" F.O., 6" long, 18 ga sheet steel, with one type 2 flange and one lap riveted seam with item 48, and two lap riveted seams.
- 50. Spool thermally insulated, 20" x 10" F.O., 6" long, 1/4" thick steel, with two type I flanges, and two welded seams.
- 51. Transformation piece, thermally insulated, 20" x 10" 20" x 10" F.O., 6" long, 18 ga sheet steel, with one type 2 flange and one lap riveted seam with item 52, and two lap riveted seams.
- 52. Straight duct, thermally insulated, 20" x 10", 86" long, with 2 lap riveted seams with items 51 & 54. Constructed of 18 ga sheet steel, and two "Pittsburgh" type seams.
- Shut-off damper for 20" x 10" thermally insulated duct, 16 ga sheet steel, with operating gear.
- 54. Transformation piece, thermally insulated, 20" x 10" 20" x 10" F.O., 6" long, 18 ga sheet steel, with one type 2 flange, one lap riveted seam with item 52, and two spot welded seams.
- 55. Spool, thermally insulated, 20" x 10" F.O., 6" long, 14" thick steel, with two type I flanges, and two welded seams.
- 56. Transformation piece, 20" x 10" 20" x 10" F.O., 6" long. 18 ga sheet steel, with one type 2 flange, one lap riveted seam with item 57, and two spot welded seams.

57.	Straight duct, 20" x 10", 10" long, with one type 3 flange and one lap riveted seam with item 61. Constructed of 18 ga sheet steel, and two
	"Pittsburgh" type seams.

- 58. Straight duct, 5" x 5", 33" long, with one type 3 flange and one lap riveted seam with item 47. Constructed of 24 ga sheet steel, with one grooved seam.
- 59. Straight duct, 8" x 16", 22" long, with one type 3 flange. Constructed of 20 ga sheet steel with one welded seam.
- 60. Straight duct, 12" x 16", 44" long, with one lap riveted seam with item 67, and one end capped and lap riveted. Constructed of 20 ga sheet steel with two "Pittsburgh" type seams.
- 61. Straight duct, acoustically insulated, 20" x 10", 114" long, with two type 3 flanges. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams.
- 62. Straight duct, 20" x 10", 35" long, with one type 3 flange, and one welded seam with item 66. Constructed of 18 ga sheet steel with two "Pittsburgh" type seams.
- 63. Orifice plate, for insertion between two type 3 flanges in 8" x 16" duct, 24 ga sheet steel.
- 64. Bolted access plate for 6" x 15" opening, 16 ga sheet steel, with gasket and 1" x 1/8" framing ring.
- 65. Headroom flange for 17" x 16" duct—two type 3 flanges modified to suit flat bottom. 1" x 1/8" steel flat bar tapping ring and 14 ga sheet steel cover plate.
- 66. Bellmouth exhaust terminal, for 20" x 10" duct. Constructed of 18 ga sheet steel with welded corner seams and welded seams with item 62. With \$2" x 32" screening and retaining ring.
- 67. Special flunge, for joining 12" x 16" duct. Flunge 12" long with two lap riveted seams with items 35 & 60. Constructed of 20 ga sheet steel with bottom plate removable.


MATERIAL COSTS

Article & Quantity	Price (\$)
24 ga galv sheet steel, 12 Ft²	2.50
22 ga galv sheet steel, 14.2 Ft ²	3.61
20 ga galv sheet steel, 135 Ft ²	40.39
18 ga galv sheet steel, 233 Ft ²	90.65
16 ga gaiv sheet steel, 10 Ft ²	4.79
14 ga galv sheet steel, 1.7 Ft ²	1.00
li ga gaiv sheet steel, 50 Ft ²	47.21
14" thick steel plate, 11 Ft ²	20.78
156" x 114" x 14" galv steel angle, 73 LF	31.43
11/2" x 11/2" x 1/4" galv steel angle, 8 LF	3.44
I" x I" x 16" galv steel angle, 66 LF	18.48
11/2" x 3/16" galv steel FB, 50 LF	11.25
11/2" x 14" galv steel FB, 2.3 LF	.66
1" x 1/8" galv steel FB, 13 LF	1.44
%" x 3/16" CRES FB, 6 LF	1.44
56" x 1/8" CRES FB. 4 LF	.30
3/16" x 1-7/16" galv steel FB. 140 LF	31.50
34" IPS half-coupling. I required	.40
Damper assemblies, balance and shut-off,	25.00
4 required - bought as units	
Spacers, % Jubing, 36" long, steel, 20 required	UC.
Splitter damper assembly, I required, bought as unit	6.00
1" x 1/16" spring steel, cad plated, 1.5 LF	.30
1½" x .05" brass strip, I LF	.75
Gasket, 1/8" cloth-inserted rubber, 20 Ft2	5,00
I" half-round bar, galv steel, 1.5 LF	.50
Fusible link, I required	.30
¾" dia shaft, CRES, 6 LF	2.70
34" dia std pipe, CRES, 4 LF	1.20
3" O.D. x %" I.D. CRES bearing plate, 3/16" thick, 5 required	1.50
11/4" O.D. x 34" L.D. CRES thrust collar, 1/2" thick, 4 required	1.00
1-9/16" O.D. x 1.1" 1.D. CRES thrust collar, 34" thick, 2 required	.75
1/8" dia brass pin, 11/2" long, 4 required	.40
1½" x 1/6" CRES FB, 1.4 LF	.40
1/4" - 20 NC-3 RH mach screws, 1" long, 20 required	.30
1/4" - 20 NC-3 hex nuts, 20 required	.20
36" - 16 NC-2 hex head bolts, 1" long, 504 required	10.00
#10 flat point thread cutting mach screws, 1/4" long, 14 required	.15


	.15
3/16" - 20 NC-3 hex head bolt. 1/2" long. 10 required	.10
3/16" - 20 NC-3 hex nuts, 10 required	7.50
36" - 16 NC-2 hex nuts, 504 required	15.00
Break-mandrel type "Pop" rivets, 1600 required	1.54
14" - 20 UNC-3B "Rivnuts," 44 required	.50
14" - 20 UNC-3B RH machine screws, 34" long. 44 required	2.60
14" - 20 NC-2 RH machine screws, 34" long, 259 required	
14" - 20 NC-2 RH machine screws, brass, 34" long, 6 required	.18
1/4" - 20 NC-2 hex nuts, brass, 7 required	.14
Washers for 34" dia bolt. 462 required	2.30
14" - 20 NC-2 hex head machine screw, brass. 11/1" long. I required	.03
Washer for 1/4" din bolt, brass. 5 required	.05
14" - 20 NC-3 hex head bolts, 114" long, 12 required	.15
14" - 20 NC-3 wing nuts, 12 required	.48
14" - 20 NC-2 hex nuts, 259 required	2.60
1/4" - 20 NC-2 hex head cone point machine screw.	.20
CRES 3/16" long. 2 required	
Lock washer for 14" bolt, brass. 2 required	.03
#10 - 32 NC-2 hex head machine screw, CRES.	.06
1½" long, 3 required	
1/2" x 1/2" wire mesh. 6 Ft ²	.90
5/32" flat CSK-head rivets. 16 required	.12
14" - 20 NC-3 flat head machine screws, 12" long. 20 required	.20
Thermal insulation, fiberglass board type, 1" thick, 67 Ft ²	20.00
Acoustic insulation, fiberglass board type, 1" thick, 48 Ft ²	14.40
Adhesive for cementing lagging cloth to insulation. I gallon	10.00
Adhesive for cementing insulation to duct. 1.5 gallons	15.00
	40.00
Vaper barrier, 4 gallons	4.60
2" glass tape, 46 LF	7.10
Lagging cloth, 71 Ft ²	30.00
Duct joint sealer, 2 gallons	

TOTAL MATERIAL COST = \$543.81

BASIC WORK FLOW DIAGRAM



WORK TASK 1 - ENGINEERING (Plan Development)




WORK TASK I - COSTS

DIRECT LABOR

		MANHOUR	2	
ITEM	MANHOURS	RATE (\$)		SUBTOTALS (\$)
la	4	7.50		30.00
lb	24	7.50		180.00
lc	4	7.50		30.00
ld	24	7.50		180.00
le	12	7.50		90.00
IC	28	7.50		210.00
lg	12	7.00		84.00
lh	4	10.00		40.00
li				
	DIRECT L	ABOR	_	: 844.00
	DIRECT M	IATERIAL	==	<u>''</u>
	INDIRECT	COST*	=	675.20
	TOTAL CO)CT	_	\$1519.20
	IOIALCO	/31		#1J1J.2U

^{* 80%} of Direct Labor

WORK TASK 2 - PRODUCTION (Material Procurement and Component Fabrication)



WORK TASK 2 — COSTS


DIRECT LABOR

ITEM	MANHOURS	MANHOUR RATE (\$)		SUBTOTALS (\$)
2n	12	6.50		78.00
2b	16	8.50		136.00
2c	266	7.00		1862.00
2d	8	6.50		52.00
2e	16	7.00		112.00
2f	8	6.50		52.00
2g	2	6.50		13.00
	DIRECT L	ABOR	_	2305.00
		IATERIAL	=	543.81
	INDIRECT		=	1152.50
	TOTAL CO	OST	_	\$4001.31
			-	

^{* 50%} of Direct Labor

MANHOURS -- WORK TASK 2C (COMPONENT FABRICATION)

liem No.	Manhours	Item No.	Munhours	Item No.	Manhours
1	3.0	24	4.0	47	3.0
	10.0	25	4.5	48	2.0
2 3	2.5	26	3.0	49	3.0
4	24.0	27	8.0	50	4.0
5	4.5	28	3.0	51	3.0
6	4.0	29	3.0	52	3.0
ž	4.5	30	3.0	53	1.5
8	16.0	31	4.0	54	3.0
9	4.0	32	1.0	55	4.0
10	2.5	33	1.5	56	3.0
11	3.0	33 34	4.0	57	4.0
			1.0	58	3.0
12	3.5	35			
13	6.0	36	1.0	59	3.0
14	3.5	37	1.0	60	2.0
15	4.0	38	2.0	61	8.0
16	4.0	39	1.0	62	4.0
17	4.0	40	3.0	63	1.0
18	2.0	41	3.0	64	2.5
19	3.5	42	2.0	65	4.0
20	6.0	43	2.5	66	3.5
21	3.0	44	2.5	67	2.0
22	16.0	45	2.5	٠,	
23	4.5	46	1.0	TOTA	L 266.0




WORK TASK 3 — COSTS

DIRECT LABOR

		MANHOUR		
ITEM	MANHOURS	RATE (\$)		SUBTOTALS (\$)
3a	6	6.00		36.00
3b	24	7.00		168.00
3c	20	7.00		140.00
3d	12	7.00		84.00
3e	8	7.50		60.00
3f	6	7.00		42.00
3g	4	9.00		36.00
3h	8	6.50		52,00
	DIRECT L	ABOR	_	618.00
	DIRECT M	IATERIAL	=	
	INDIRECT	COST*	-	247.20
	TOTAL CO	OST	=	\$865.20
			=	

^{* 40%} of Direct Labor



WORK TASK 4 — COSTS

DIRECT LABOR

		MANHOUR		
ITEM	MANHOURS	RATE (\$)		SUBTOTALS (\$)
4a	2	8.00		16.00
4b	1	8.00		8.00
4c	2	8.00		16.00
4d	8	8.00		64.00
4e	_			_
	DIRECT I.	ABOR		104.00
	DIRECT M	IATERIAL	*	
	INDIRECT	COST*	=	31.20
	TOTAL CO	OST	-	\$135.20
			_	

^{* 30%} of Direct Labor

SUMMARY — COSTS

Work Task	Direct Labor (\$)	Direct Material (\$)	Indirect Cost (\$)	Sub- Total (\$)
1	844.00		· 675.20	1519.20
2	2305.00	543.81	1152.50	4001.31
3	618.00	_	247.20	865.20
4	104.00		31.20	135.20
TOTALS	\$3871.00	\$543.81	\$2106.10	\$6520.91

Note — Due to the wide variance existing throughout the industry in labor rates and indirect costs, only the material costs and manhour estimates are considered to be significant factors of reasonable reliability.

APPENDIX E

AREAS FOR FUTURE STUDY

The researcher's recommendation for areas of future study that have the greatest potential for cost savings are discussed herein.

INTRODUCTION

The following discussion presents proposals and recommendations for areas of future study. Many of these can be reduced or increased in scope, depending upon the reviewing activity. However, John J. McMullen Associates. Inc. (JJMA) considers that these items are representative of the areas of greatest potential cost savings and/or improvement for American-built merchant ships.

Certain of the proposed recommendations are a result of encountering unresolved problems whose resolution is beyond the scope of this project. Others have been suggested to afford the shipbuilding industry cost-saving innovations and practices similar to those generally available to shoreside design and construction activities.

DUCT PRODUCTION AND FABRICATION

As part of this project, detailed research has been directed towards the practices followed in the commercial shoreside HVAC industry. Certain of the information gathered in this effort has been associated with the layout, work and material flow. and machinery used within sheet metal shops, with regard to minimizing costs. While it is obvious that the problems faced by a shipyard are more complex than those encountered ashore, it would seem that certain of the principles are especially significant to duct standardization and cost savings. It is therefore recommended that a study be undertaken to determine if a feasible production line type of duct fabrication process may be developed to suit the diversity of the marine industry. While some shippards might already be utilizing such a concept JJMA suggests that the additional advice of experts in the field of shoreside sheet metal fabrication, work flow processes, and manufacturing of associated machinery, may result in additional economical advantages. Any such effort would have to be undertaken with due respect to agreements and contracts between shipyards and their union associations. If agreeable to those concerned, the study should be accomplished through joint input from shipyard fabrication personnel and from an organization experienced in studies of this type.

In conjunction with the above recommendation, JJMA also suggests that shipvard personnel associated with sheet metal fabrication be given the opportunity to review and comment on some of the new machinery, tools, and sheet metal forming methodology now available. While JJMA is primarily concerned with the design phase of most projects, and shop personnel are more closely involved with the actual details and problems of fabrication and construction, there are several innovative devices now on the market, both motor-driven and manual, that offer the promise of increased productivity. There is also an abundance of fabricated parts and ducting components which are available. JJMA has found that an excellent source of such items, and articles associated with the commercial sheet metal trades, is "SNIPS" Magazine. Inc. Included in this review should be an investigation of some of the recent developments regarding the internal environment of workshops where operations are performed which give off toxic or annoying fumes (welding, burning, etc.). The energy shortage has resulted in designs which are directed at least cost/energy usage. The concepts involved with such designs are not unknown to shipyard personnel, however, some of the new hardware may be.

PRESSURE DROP TEST PROGRAM

It is proposed that a testing program be instituted to determine the pressure drop losses associated with duct branch take-offs (taps), especially on the return/exhaust side of HVAC systems. While branch take-off losses on the supply side of systems have been fairly well determined and documented (at least for round duct), return-side losses have not been subjected to the same degree of resolution. Most of the trade data sources state this condition, and where factors are given, they are noted to be only those generally used and not substantiated by a testing program. While the U.S. Navy gives values in their Design Data Sheets, an examination of these will indicate that they are unsatisfactory for all branch/main air ratios. Many design organizations utilizing these Design Data Sheets revise these values to suit such ratios. But the results of these revised values have not been confirmed.

The main objectives of the proposed testing program are:

- Determine duct take-off pressure drop losses for branch and main sections.
 on both the supply and return side of systems.
- Determine the geometric relationships of branch to main configurations which result in the least pressure drop losses, and which are most easily constructed.
- Determine the pressure drop loss variations between single and multiple take-off connections at the same point on the main section.
- The above to be determined for both symmetrical and non-symmetrical take-off connections (connecting ducts centerline relationship), with equal and unequal air velocities in the branch and main ducts.
- Testing and analyses to cover the full range of air velocities normal to marine projects, for both round and rectangular ducts and combinations thereof, and for the full range of expected branch/main air quantity and velocity ratios.

The results of such a testing program will make available to system designers data more reliable than what they presently use, and will therefore eliminate some of the problems encountered during system test and balance procedures. In addition, a basic contribution of the program—should configurations be found with reasonably low pressure drop losses—would be the elimination of many of the split mains now used in favor of the more easily constructed take-off concept. This would not only result in savings to the fabrication activities, but would also give the system designer more freedom of choice. The above would also serve to further reduce (perhaps significantly) the number of specific sizes as proposed in the basic standardization program.

COMPUTER PROGRAMS

Although there are numerous duct pressure drop computer programs available for use by commercial shoreside HVAC design activities, there is a definite lack of a comprehensive program to suit marine HVAC installations. The low air velocities generally found in shoreside installations, the different design parameters, (space availability, system function, length of run, equipment types, specific air flow conditions, duct component type, etc.), and the actual basis of calculations, make the use of programs designed for shoreside installations impractical for marine installations unless substantial program revision, review and in many cases, rework, is accomplished.

There are programs available which were developed for marine installations by various design agents and shippard design functions. However, from review and use of certain of these. JJMA feels that none are fully responsive to the limiting design conditions peculiar to marine installations, especially when considered in respect to standardized duct sizes and components, and to cost savings from fubrication and installation activities.

It is therefore proposed that a pressure drop program be developed specifically for marine designs, and that it consist of a two-stage procedure. The first stage would give preliminary sizing information to the designers for use during the initial design phase. The second stage would produce the final pressure drop calculations and duct sizes subsequent to the systems design/coordination phase. The two stages should be so organized, and the initial stage so developed that any differences in their duct size outputs (due to changes necessary during the coordination phase of design) are small enough to be accommodated without the need for repeated systems coordination.

The program should be developed to create a standard of HVAC system air flow performance for American shipbuilding interests, and be arranged so that any necessary program changes/adjustments at later dates may be easily incorporated. It should include an extensive input data checking procedure, be capable of accom-

modating both complete and partial systems, be capable of achieving system balance within the constraints of the proposed standard sizes and components, and accomplish the necessary evaluations to maximize cost savings in the fabrication and installation activities. It is estimated that a savings of 75 percent would ultimately result in the design activity alone (over the cost resulting from hand calculations) through the use of such a computer program. The development of this program could also include provision for two other functions; HVAC noise calculations, and system material requirements. This would further reduce the need for hand calculation, and in the case of noise calculations, would also reduce the extent of any corrective action after system installation and testing.

It is also proposed that a computer program be developed to perform space heating/cooling load calculations on a standard basis for merchant ships. The program should have, as a major part of its contents, all "U" factor information as set forth in the S.N.A.M.E. Technical and Research Bulletin 4-7, "Thermal Insulation Report." It should be capable of selecting summer, winter, and change-over, "U" factor values, and of interpolating between end values as given in the cited report. As with the proposed duct pressure-drop computer program, it should have an extensive input data checking procedure, and be capable of printing out all pertinent outputs in a format easily utilized by design personnel. Major design parameter values which may change from ship to ship (weather conditions, personnel loadings, space temperatures, glass transmittance values, etc.) should be read by the computer as problem input variables so that the program is as versatile as possible.

THERMAL INSULATION

At present, the U.S. Navy is eliminating thermal insulation on supply side air conditioning ductwork, depending on the relationship existing between the dry bulb temperature of the air within the duct and the wet bulb temperature of the air surrounding the duct. Further, in areas where this relationship would necessitate insulation, the system designer has the option of either specifying insulation or providing by-pass air on the system so that insulation is not required. Thermal insulation on the return side of an air conditioning system is, in general, not required. Thermal insulation requirements on ducting of supply and exhaust systems is specified in section 509 of the U.S. Navy General Specifications, with an easily followed format. JIMA has noted the effect of minimizing insulation on Naval ships in accomplishing various tasks for the Naval Ship Engineering Center. Except for some specific instances, little condensation has been observed. One observation within a scullery showed that the occurrence of condensation on uninsulated ductwork was dependent on the existence of paint on the exterior surface of the ducting. Immediately after space usage, condensation was observed on painted supply duct, but none on unpainted galvanized steel duct on the same system.

Based on the above, it is proposed that a study be undertaken to determine the minimum thickness and type of insulation required for duct work commensurate with condensation and heat transfer considerations. The basic objective is to reduce, or eliminate, as much of the presently required thermal insulation as possible.

Thermal insulation on all duct cannot be eliminated totally. However, for many cases where elimination is not possible, the amount required can be reduced. In addition, for borderline cases, the application of an insulating paint or similar coating may serve the purpose. Since the application of insulation is a costly item, requiring in many cases considerations such as vapor sealing, portable pieces for flanges, access plates, etc., the need for such a study seems evident.

HVAC EQUIPMENT

There have been substantial advances in HVAC equipment design to suit the commercial shoreside trade in the past 15 years, as well as broad developments in methods and concepts for protecting material from adverse environmental conditions. These should be investigated with respect to their particular application to marine projects. New equipment types have been designed and built for the U.S. Navy, including larger cooling coils and a new family of sizes of fan coil units. These items should also be investigated for applicability to commercial marine projects.

In conjunction with the above, it is proposed that a study be undertaken to review, update, and/or change, the type of HVAC equipment presently required for installation on American flag ships. Few equipment manufacturers have been responding to requests for bids on marine projects. Some have stated that they do not wish to bid on marine projects due to the specialties involved, and the increasing costs and scarcities of certain of the materials required to meet specifications.

One of the common problems faced by equipment manufacturers is that of tooling and work scheduling to suit marine requirements, and of having large periods of time in which the need for their product is not in reasonable demand. It may be desirable to have equipment types which, except for military shock grading, are applicable for both naval and commercial marine designs. Trade-off analyses should be accomplished concerning items such as adjustable pitch direct drive vaneaxial fans (similar to the Buffalo Forge Co. "Adjustax" series) which may be adjusted for capacity control after installation. The trade-offs should include the extra cost for such equipment versus the time saved during the system testing and balancing procedures.

A study of this type should be accomplished through a joint effort of both equipment manufacturers and representatives of the marine design field. Owners'

requirements and crew and operating personnel complaints should serve as an input to such a study as well as survey reports of equipment installed on existing ships of various ages.

CONSTRUCTION DETAILS

It is the opinion of JJMA that there is a definite need to establish a standard booklet of construction details, resulting in the simplification of existing methods and the minimization of the number of source materials. As part of this development, cognizance should be taken of the large selection of components and associated hardware available from the various American manufacturers. In addition, all construction details should be so arranged that make/buy decisions will not affect connecting components, or the component into which the bought item is to be inserted, if such is the case.

SPECIFICATIONS

It is proposed that the standard Marad specification format for Section 7 (Insulation, Linings, and Battens) insofar as compartment thermal and acoustic insulation is concerned, Section 12 (Air Conditioning, Heating and Ventilation), and Section 64 (Machinery Space Ventilation), be rewritten similar to the format used in the U.S. Navy specifications. Section 509 (Thermal Insulation and Acoustic Absorptive Treatment for Ducts and Trunks), section 512 (Air Conditioning, Ventilation and Heating), and Section 635 (Thermal Insulation and Acoustic Absorptive Treatment of Compartments for Surface Ships). In addition, any such redevelopment of Section 12 of the standard Marad specification should contain a definitive set of instructions regarding the U.S. Coast Guard's fire protection requirements as applicable to HVAC systems, and an explanation of rat proofing requirements for interspace protection.

In conjunction with this effort, it is also recommended that a compartment insulation chart be developed similar to that found in Section 635 of the U.S. Navy specifications, and a Design Criteria Manual be developed for merchant ships, similar in format and content to that developed by the U.S. Navy. "Air Conditioning, Ventilation and Heating Design Criteria Manual for Surface Ships of the United States Navy" (N.S. 0938-018-0010).

This recommendation has been made in the belief that a more explicit set of specifications will better serve both the design functions and the shipowners, as well as facilitate checking by the owners' representatives. Some of the ambiguities and arguments which presently occur will vanish. A redevelopment of the specifications can be made in such a manner as to easily accommodate any specific changes found desirable for any particular ship.

CONCLUSION

In making the above proposals and suggestions, JJMA realizes that some personnel, intimately associated with marine type HVAC installations, will strongly disagree with the degree of economic savings and benefits to the ship. It is also true that design, fabrication, and installation practices differ between the various ship-yards, and therefore what benefits one may be found costly to another. JJMA has attempted to analyze the proposals in a manner to assure that effort has been directed toward the formulation of cost reducing innovations. All comments, arguments, and counter-proposals from American shipyard personnel and from the shipbuilding industry are not only welcome, but necessary in furthering the cost saving features of the National Shipbuilding Research Program studies.

APPENDIX F

DUCT SIZE UTILIZATION — FIRST GENERATION OF SPLITS

This is a listing of first-generation standard splits from standard duct.

STANDARD DUCT SIZE		STANDARD SPLITS	
DEPTH(IN.)	WIDŢH(IN.)	DEPTH OF SPLITS (INCHES)	WIDTH OF SPLITS (INCHES)
2	4 `		
	6		
	. ' 8 .		4
4	4	2	2
	6	2	2,4
	8	2	2.4,6
	10	_	2,4,6.8
	12		2,4,6,8,10
	14		2,4,6,8,10,12
6	6	2,4	2,4
-	8	2,4,6	2.4.6
	10		2,4,6,8
	12		2-10 in 2 inch increments
	14		2-12 in 2 inch increments
	16		2-14 in 2 inch increments
	18		2-16 in 2 inch increments
8	8 .	2,4,6	2,4.6
	10	4	2,4,6,8
	12	4	2-10 in 2 inch increments
	14	4	2-12 in 2 inch increments
	16		2-14 in 2 inch increments
	18		2-16 in 2 inch increments
	20		2-18 in 2 inch increments
	22		2-20 in 2 inch increments
	24	_	2-22 in 2 inch increments

STANDARD	DUCT SIZE	STAND	ARD SPLITS
		DEPTH OF	WIDTH OF
DEPTH(IN.)	WIDTH(IN.)	SPLITS (INCHES)	SPLITS (INCHES)
10	10	4,6	4,6
	12	4,6	4.6.8
	14	4,6	4.6.8.10
	16		4-12 in 2 inch increments
	18	_	4-14 in 2 inch increments
	20		4-16 in 2 inch increments
	22	_	4-18 in 2 inch increments
	24	_	4-20 in 2 inch increments
	26		4-22 in 2 inch increments
	28		4-24 in 2 inch increments
·	30		4-26 in 2 inch increments
12	12	4.6.8	4.6.8
	14	4,6.8	4,6.8,10
	16	6	4-12 in 2 inch increments
	18	6	4-14 in 2 inch increments
	20	_	4-16 in 2 inch increments
	22	_	4-18 in 2 inch increments
	24		4-20 in 2 inch increments
	26	_	4-22 in 2 inch increments
	28	***	4-24 in 2 inch increments
	30	_	4-26 in 2 inch increments
	32		4-28 in 2 inch increments
	34		4-30 in 2 inch increments
	36	_	4-32 in 2 inch increments
14	14	4.6,8,10	4,6,8,10
	16	6,8	4-12 in 2 inch increments
	18	6,8	4-14 in 2 inch increments
	20		4-16 in 2 inch increments
	22		4-18 in 2 inch increments
	24		4-20 in 2 inch increments
	26		4-22 in 2 inch increments
	28		4-24 in 2 inch increments
	30	·	4-26 in 2 inch increments
	32	_	4-28 in 2 inch increments
	34		4-30 in 2 inch increments
	36	_	4-32 in 2 inch increments
	38	_	4-34 in 2 inch increments
	40		4-36 in 2 inch increments
	42		4-38 in 2 inch increments

STAN		STANDARD SPLITS	
	312.2	the state of the s	
DEPTH(IN.)	WIDTH(IN.)	DEPTH OF SPLITS (INCIIES)	WIDTH OF SPLITS (INCHES)
16	16	6.8.10	6,8,10
	18	6,8,10	6-12 in 2 inch increments
	20	8	6-14 in 2 inch increments
	22	8	6-16 in 2 inch increments
	24	8	6-18 in 2 inch increments
	26		6-20 in 2 inch increments
	28		6-22 in 2 inch increments
	30		6-24 in 2 inch increments
	32		6-26 in 2 inch increments
	34		6-28 in 2 inch increments
	36	•	6-30 in 2 inch increments
	38		6-32 in 2 inch increments
	40	_	6-34 in 2 inch increments
	42	-	6-36 in 2 inch increments
	44	_	6-38 in 2 inch increments
	46	_	6-40 in 2 inch increments
	48		6-42 in 2 inch increments
18	18	6.8,10.12	6,8,10,12
	20	8.10	6-14 in 2 inch increments
	22	8,10	6-16 in 2 inch increments
	24	8,10	6-18 in 2 inch increments
	26		6-20 in 2 inch increments
	28		6-22 in 2 inch increments
	30		6-24 in 2 inch increments
	32		6-26 in 2 inch increments
	34		6-28 in 2 inch increments
	36	-	6-30 in 2 inch increments
	38		6-32 in 2 inch increments
•	40		6-34 in 2 inch increments
	42	_	6-36 in 2 inch increments
	44		6-38 in 2 inch increments
	46		6-40 in 2 inch increments
	48		6-42 in 2 inch increments
	50	_	6-44 in 2 inch increments
	52		6-46 in 2 inch increments
	54	****	6-48 in 2 inch increments

STANDARD DUCT SIZE		STANDARD SPLITS	
DEPTH(IN.)	WIDTH(IN.)	DEPTH OF SPLITS (INCHES)	WIDTH OF SPLITS (INCHES)
20	20	8,10,12	8,10,12
	22	8,10,12	8.10,12,14
	24	8,10,12	8,10,12,14, 16
22	22	8,10,12,14	8,10,12,14
	24 .	8,10,12,14	8,10,12,14,16
24	24	8.10,12,14,16	8,10,12,14,16

APPENDIX G

COST ANALYSIS

Costs for various transverse connections, transformation pieces, access plates and a bellmouth terminal are itemized herein. Costs are in February 1976 dollars.

- 1.0 Cost Analysis: Flanged vs. Non-Flanged Transverse connections, comparison basis = 12-inch by 24-inch duct
- 1.1 Flanged Type 4A; riveted angle flange, reinforced

Net material required:	Cost (\$)
• 1" X 1" X 1/6" steel angle. 4-26" lengths	2.17
• I" X I" X 1/8" steel angle, 4-12" lengths	1.00
• 2814" 20 NC RH MS. 34" LG	.45
• 28¼" 20 NC hex nuts :	.31
• 2-72" X 1" 20 ga additional material on duct components	.30
• 88-3/16" dia "pop" rivets	1.58
• 76" strip of 1" wide. 1/6" thick gasket	.21
• Duct sealer (2-72" lengths & 88 rivet heads)	2.00
Total material cost	s = \$8.02

Fabrication effort required:	Time (Min)
Measure and cut 4-26" lengths of angle	15
Measure and cut 4-12" lengths of angle	15
Weld 8 corners	120
Drill or punch 56-"/22" dia holes in angles	30
• Drill or punch 88-3/14" dia holes in angles	40
Drill 88-3/16" dia holes in components!	40
 Install and set 88-3/14" dia "pop" rivets! 	45
Seal 88 rivet heads¹	20
• Seal 2-72" lengths'	20
 Measure and cust 2-26" X 1" and 2-12" X 1" lengths of gaskets¹ 	15
 Align gasket on flange and drill 28-"/a2" dia holes! 	10

Total time required = 370 Min.

Installation effort required:

Time (Min)2

• Align components, install and tighten 28-1/4" dia nuts and bolts

Total time required = 60 Min.

1.2 Non-flanged Types 10 & 11, drive cleat/S-clip

1.2.1 Types 10 & 11

Drive cleats assumed on 12" side of component, and S-clip assumed on 24" side of component.

Net material required:	Cost (\$)
• 2-15' X 214" strips of 20 ga steel (Drive cleats)	.14
• 2-24" X 31/4" strips of 20 ga steel (S-clips)	.35
Duct sealer (2-72" lengths)	1.80
• 4-1" X 24" 20 ga additional material on duct components	.20
• 4-1" X 12" 20 ga additional material on duct components	.10
Total material co	

Fabrication effort required:	Time (Min)
••	, , , , , , , , , , , , , , , , , , ,
 Measure and cut 2-15" X 2¼" pieces of 20 ga steel 	10
Notch to suit locking tabs (4)	20
Bend over form to shape 2 drive cleats	20
 Measure and cut 2-24" X 3½" pieces of 20 ga steel 	15
Notch to suit component corner connections	20
Bend over form to shape 2 S-clips	30
Bend 4-12" X ½" tabs on components	. 40
Total time req	uired = 155 Min

Installation effort required: • Align components and install 2 S-clips • Install side drive cleats and bend 4	Time (Min) ² 10
locking tabs over	20
• Scal 2-72" lengths	20

Total time required = 50 Min.

1.2.2 Type IIA; drive cleat/S-clip, reinforced

Drive cleats assumed on 12" side of component, and S-clips with transverse reinforcement assumed on 24" side of component.

¹Dependent on the shipyard, a high percentage of these tasks may be accomplished aboard ship during the installation procedure.

²Average time, assuming some difficulty due to limited space.

Net Material required:	Cost (\$)
 Same as for non-flange types 10 & 11 	2.59
• Plus 2 additional 24" X 21/2" strips of 20 ga stee	el <u>.25</u>
	Total material cost = \$2.84
Fabrication effort required:	Time (Min)
Same as for non-flange types 10 & 11 Plus the additional work required to	155
form the reinforcing part of the S-clips	20
•	Total time required = 175 Min
Installation effort required:	Time (Min)
Same as for non-flange types 10 & 11	50
	Total time required = 50 Min
1.2 Now Element Time to siveted stim joint	

1.3 Non-Flanged Type 9; riveted slip joint

Cost analysis based on riveted joint'

• 2 - 1" X 72" 20 ga additional material on duct components

Net material required:

• 76 - 3/11" dia "pop" rivets	1.80
Duct sealer (1 - 72" length)	90
Total material co	osts = \$3.00
Fabrication effort required:	Time (Min)
• Drift 4-3/14" dia holes in end of one component	5
Attach 2 components and drill through	
4 holes into second component	10
Set 4 - "/is" dia "pop" rivets	5
 Drill remaining 72 - 3/16" holes through both components 	70
• Set remaining 72 - 3/18" dia "pop" rivets	40
• Seal 72" length	10
Total time required	= 140 Min

Installation effort required: None. It is $r \bowtie field$ connec. I. It is totally fabricated in the shop.

1.4 Non-Flanged Type 12; clip & strike latch

1.4.1 Type 12

Cost (\$)

.30

Latches and strikes on 24" side of components, therefore, 4 required (2 on each 24" side)

Net material required:	Cost (\$)
• 4 - latches	1.20
• 4 - strikes	.20
• 4-1/s" dia cotter pins, 1" long	.10
• 1" X 72" strip of 20 ga steel (additional on component	
which carries the latches)	.15
• 72" X 2¼" strip of 20 ga steel (for retaining clip)	.34
• 24 - 3/32" dia round head rivets	.24
• 38 - 3/18" dia "pop" rivets	.90
Duct seuler (2 - 72" lengths)	1.80
Total material co	st = \$4.93

Time (Min) Fabrication effort required: • Measure and cut 2-24" X 21/4" strips of 20 ga steel 15 • Notch to suit component corner seams (4) 10 • Shape 2 - 24" lengths of retaining clip 30 • Measure and cut 2 - 12" X 214" strips of 20 ga steel • Notch to suit component corner seams (4) • Shape 2 - 12" lengths of retaining clip 20 • Drill or punch 38 - "/1" dia rivet holes in retaining clips 40 • Drill 38 - ²/18" dia rivet holes in component 40 • Install and set 38 "pop" rivets 20 • Peen end of component carrying latch over 1/2" (72" long) 40 • Locate latches and strikes and drill 24 - 3/32" dia rivet holes 30 • Install and set 24 rivets (with rivet set) 25 • Seal 72" length 10 Total time required = 300 Min

Installation effort required:
Seal 72" length of retaining clip
Bring components together and secure latches
Install and set 4 cotter pins

Time (Min)
10
10
5

Total time required = 25 Min

¹Net material cost and fabrication effort would be somewhat less for a spot-welded connection than for a riveted connection. However, most shops do not have the specialized welding equipment necessary for this purpose.

1.4.2 Type 12A (with reinforcement)

Latches and strikes on 24" side of components, therefore, 4 required (2 on each 24" side)

Net material required:	Cost (\$)
• 4 - latches	1.20
• 4 - strikes	.20
• 4 - Strikes • 4 - 1/8" dia cotter pins, 1" long	.10
• 72" X 3½" strip of 20 ga steel	
	.53
(for retaining clip)	.24
• 24 - ³/ʒ²" dia round head rivets	.52
• 22 - ³ /16" dia "pop" rivets	1.80
• Duct sealer (2 - 72" lengths)	
Total mater	rial cost = \$4.59
Fabrication effort required:	Time (Min)
 Mensure and cut 2 - 24" X 3½" strips of 20 ga steel 	15
Notch to suit component corner seams (4)	10
Shape 2-24" lengths of retaining clip	40
 Measure and cut 2 - 12" X 3½" strips of 20 ga steel 	10
Notch to suit component corner seams (4)	10
Shape 2-12" lengths of retaining clip	30
• Drill or punch 22 - "/16" dia rivet holes in retaining clips	25
• Drill 22 - 3/10" dia rivet holes in component	25
• Install and set 22 "pop" rivets	15
• Locate latch and strikes and drill 24 - 3/32" dia rivet holes	30
• Install and set 24 rivets (with rivet set)	25
• Seal 72" length	10
	uired = 245 Min
Installation effort required:	Time (Min)
Same as for non-flange type 12	25
	equired = 25 Min

1.5 Summary: Flanged versus Non-flanged Connections (12" x 24" component size)

	material cost	fabricate time	install time
Base: Current Type 4A, riveted angle flange, reinforced	\$8.02	370 min.	60 min.
Standard Type 10/11, drive cleat/S-clip	2.59	155	50
Standard Type 11A. drive cleat/ S-clip reinforced	2.84	175	50
Standard Type 9, riveted slip joint	3.00	140	N/A
Standard Type 12. clip and strike latch	4.93	300	25
Standard Type 12A, clip and strike latch	4.59	245	25

2.0 Transformation Piece

2.1 Type I

Material has been considered a trade-off with Type 2.

Fabrication method has been assumed to be based on a two-piece transformation, and two-Pittsburgh corner locks.

Fabrication effort required:	Time (Min)
Calculate L2 and L3	15
Layout 1/2 pattern on sheet metal	15
Add allowance for corner locks and transverse connections	10
• Cut out piece	15
Use cut-out piece for template of second	
piece and scribe on sheet metal	5
Cut second piece	15
Cut necessary corner notches	10
Run corner locks and single locks (2 each)	20
Bend each piece (2 bends)	10
Assemble transformation and bend over two corner locks	20
Total time requi	red = 135 Min

2.2 Type 2 Material cost has been considered a trade-off with Type-1.

Fabrication method has been assumed to be based on a two-piece transformation, and two-riveted, spot welded, or grooved seams.

Fabrication effort required:	Time (Min)
• Calculate 1.2 & 1.3	15
Determine length of bend lines within	
radius corner area	30
Determine distance between bend lines at intersection	
with plane perpendicular to air flow at	
radius corner end of transformation	10
 Layout 1/4 pattern and use to scribe two - 	
1/2 layouts on sheet metal	40
 Add allowance for corner locks and Transverse connections 	10
Cut out two pieces	30
Cut necessary corner notches	10
 Bend each of two pieces along bend 	
lines to 90° (4 such bends)	40
Align 2-transformation halves and clamp together	10
• Drill 20 - "/ıa" dia holes	. 20
• Set 20 - ⁴ /16" dia "pop" rivets	10
Total time required	d = 225 Min

3.0 Quick-Acting Access Plates

3.1 Round Access Plate (assume 8" dia opening — 5 locking bolts)

	,
Net material requirements:	Cost (\$)
• 1/a" thick steel (cover)	.45
• 1/4" thick gasket	.16
• 5 - 1/4" dia hex head machine screws, 1-1/4" long	.02
• 5 - 1/4" dia wing nuts	.04
• 16 ga coaming	28
	Total material cost = \$.95

Fabrication effort required:		Time (Min)
• Scribe cover on 1/4" plate and cut out	•	20
Cut access hole in duct component		10
Cut out coaming		10
 Form coaming 		10
 Shape coaming leg in way of machine 		
screws to lock hex heads (5)		20
 Weld coaming to duct 		15
Cut out and attach gasket	• •	. 10
_	-4	

Total time required = 95 Min

3.2 Alternate Fasteners for Bolted Access Plates

Watertight Duct (gasketed access cover)	Cost (\$)
Present Practice:	
• ¾" dia hex head bolt, I" long	.04
Countersunk "RIVNUT" with locking feature!	72
Cost per fastener asse	embly = $$.76$
Proposed Change:	

• 3/14" dia hex head bolt. I" long				.03
 "KWIK-THRED" self-clinching fustener 	3			
	Cost per	r fast	ener assem	bly = \$.09

Air tight duct (gasketed access cover)	Cost (\$)
Present Practice:	
• 1/4" dia RH MS, 3/4" long	.02
 Countersunk "RIVNUT" with locking feature! 	30

Cost per fastener assembly = \$.32

Proposed Change:		
 ¼" dia RH MS, 3/4" long 		.02
 "KWIK-THRED" self-clinching fastener 	•	.05
	Cost per fastener assembly	= \$.07

¹Only that effort involved with the fluired portion of the bellmouth has been listed, since the remaining work will not be affected.

²Development of one end curve has been assumed, which will serve as template for all 8 such curves

required.

*Template of end curve assumed available from set of seven master templates.

4.0 Bellmouth Terminal (D = 12", W = 18")

Material for flair (by current Method A). R = 2-1/4'', V = 3.53'':

	Cost (\$)
• 2 - 3.53" x 22.5" 20 ga steel	.33
• 2 - 3.53" x 16.5" 20 ga steel	24
	Total cost (flair) = \$.57
Fabrication effort for flair (by current Method A):	Time (Min)
• layout 2-18" sides with end curves ²	40
• layout 2-12" sides with end curves ²	10
• Cut out 4 components	30
Bend 4 components to required radius	30
Weld 4 corners	40
	il time required = 150 Min
Material for flair (by standards) $R = 3''$, $V = 4.71''$:	
'	Cost (\$)
• 2 - 4.71" x 24" 20 ga steel	.47

o a min man ar garant	
• 2 - 4.71" x 18" 20 ga steel	35
	Total cost (flair) \$.82
Fabrication effort for flair (by standards):	Time (Min)
• layout 2-18" sides with end curves	10
• layout 2-12" sides with end curves	10
• Cut out 4 components	30
Bend 4 components to required radius	30
Weld 4 corners	40

Total time required = 120 Min

^{&#}x27;Only that effort involved with the flaired portion of the bellmouth has been listed, since the remaining work will not be affected.

*Development of one end curve has been assumed, which will serve as template for all 8 such curves

required.

*Template of end curve assumed available from set of seven master templates.

APPENDIX H

SPECIFICATION TO INVOKE STANDARDS FOR RECTANGULAR VENT DUCTS

This is a recommended specification for owners or designers who wish to invoke the standards in new construction. It is a modification of the Maritime Administration Standard Specification for Cargo Ship Construction, Section 12, Article 10, 'Trunks, Ducts, Accesses and Hoods.'

10. TRUNKS, DUCTS, ACCESSES & HOODS

Duct Air Velocities

(a) Air Conditioning Systems

5000 f.p.m. maximum, except that 6000 f.p.m. may be used in short branches close to the fan discharge when necessary to absorb static pressure.

(b) Mechanical Ventilation Systems (Supply and Exhaust)
In areas where quiet operation is essential, 2000 f.p.m. maximum. Where space conditions necessitate, local velocities may be as high as 2500 f.n.m.

In areas where quiet operation is not essential, duct velocities may exceed 2000 f.p.m. as approved, provided the fan size and rated horsepower are not increased to accomplish this.

(c) Cargo Hold Mechanical Supply Systems 3500 f.p.m. maximum.

Central Cargo Hold Dehumidification Dry Air Ducts 2000 f.p.m. maximum.

- (d) Machinery Ventilation Systems (Supply and Exhaust) 3500 f.p.m. maximum.
- (e) Natural Vent Ducts Serving Mechanically Ventilated Spaces (Supply or Exhaust Direct or Indirect)
 1000 f.p.m. for less than 4000 c.f.m.
 1250 f.p.m. for between 4000 6000 c.f.m.
 1500 f.p.m. for more than 6000 c.f.m.
- (f) Natural Vent Ducts Serving Naturally Ventilated Spaces 800 f.p.m. (assumed for sizing of ducts)

Definition of Requirements

Watertight

Duct components designed and fabricated to offer the vessel protection against flooding from either inside or outside the component. These shall be of all welded construction and shall have either welded transverse joints, or properly gasketed flange joints.

Non-tight

Duct components not required to be watertight. These shall be designed and fabricated so as to offer minimal air leakage.

Air-tight

Duct components designed and fabricated similar to non-tight components, but sealed to pass a suitable pressure

test.

"A" Class Fire Protection

Duct components designed and fabricated to offer "A" Class fire protection, as defined by USCG Regulations.

"B" Class Fire Protection

Duct components designed and fabricated to offer "B" Class fire protection, as defined by USCG Regulations.

Drip-tight

Duct components designed and fabricated so that occasional water introduced into the system weather openings will not seep through the duct seams.

Material Requirements

Duct components shall be made of hot-dipped, galvanized sheet steel (or otherwise suitably protected, as approved). The minimum thickness of the duct material shall be determined by the diameter for round ducts, or the largest cross-sectional

dimension for rectangular ducts, as follows:

All non-tight and air-tight ducts 24 in-20 USSG (.0359 inch) ches or less. Satisfies "B" Class fire protection requirements. All non-tight and air-tight ducts over 24 16 USSG (.0598 inch) inches. Satisfies "B" Class fire protection requirements. All duct components exposed to 11 USSG (.1196 inch) weather. All water-tight duct components. All duct components satisfying "A" Class fire protection requirements. All duct components subject to damage (outside of .argo holds). All horizontal duct components in 3/16 inch cargo holds.

Spiral wound non-tight and air-tight round duct, up to 12 inches diameter, may be 22 USSG (.0299 inch). This also satisfies "B" Class fire protection requirements.

holds.

All vertical duct components in cargo

Size, Fabrication and Installation Requirements

Where possible, rectangular duct component sizes, design, fabrication, connections, coaming corner radii, and duct access, shall be in accordance with the "Designers Pamphlet" and "Construction Drawings" as developed for the National Shipbuilding Research Program regarding rectangular duct standards, Todd Seattle Drawing Nos. 4966 SK - 006 and - 007 respectively. (Refer U.S. Department of Commerce Contract 2-36233.)

Round ducts, depending on usage (non-tight, air-tight, watertight, etc.), may be of the spiral wound, welded, riveted, seamless, or grooved seam types. Where required for air-tightness, an approved fire resistive high velocity duct sealer or tape may be used.

All installed watertight, air-tight, and drip-tight a ct-work shall be proven so prior to the installation of insulation.

Built-in trunk construction shall not be used for ducts having less than one source foot cross-sectional area, and smaller dimension less than 9 inches.

All ducts passing over electrical equipment shall be either of watertight construction, or made drip-tight by welding or soldering the longitudinal seams on the bottom of the duct. Ducts shall be arranged to preclude non-welded transverse duct connections over electrical equipment. In addition, such ductwork shall be insulated and vapor sealed, where an analysis of the dry bulb temperature inside the duct and the dew point temperature outside the duct indicates that condensation can occur on the outside surfaces of the duct.

Access holes with suitable cover plates shall be provided for cleaning and maintenance of equipment and ducts.

Hinged doors for access shall be provided as follows:

- (1) Entrance to plenums for servicing filters.
- (2) Both sides of cooling coils.
- (3) At discharge side of axial fans larger than 24 inch diameter.
- (4) In joiner ceilings for access to concealed equipment (heaters, access plates, valves, vents, controls, dampers, etc.) size shall be at least 24 inch x 24 inch, and location shall favor equipment most frequently requiring inspection and servicing.

Provision shall be made for making ducts portable where required.

Flexible duct connections shall be used at room air mixing boxes. These connections shall be limited to 24 inch length.

All openings on the lowest weather decks shall have hinged watertight metal covers, except for air lift type openings fitted with louvers which may be furnished with protective covers as specified in Section 22. Covers shall be provided for all openings exposed to the weather.

Turning vanes or bar grids shall be provided to achieve uniform air flow to registers, grilles and diffusers.

Gaylord exhaust ventilators or equal of the latest design (including quick release automatic fire damper, automatic hot water cleaning facilities, necessary hot water and drain piping, and grease extracting facilities) shall be provided over the ranges, fryers, griddles, steam kettles, steam cookers and bake ovens.

1/4 inch

APPENDIX I

SURVEY OF FABRICATORS

A survey of a representative cross-section of U.S. sheet metal fabricators was conducted to solicit comments concerning construction/fabrication of the standard rectangular duct fittings and components, and then willingness to furnish and/or stock the components.

Various manufacturers of commercial shoreside ventilation ductwork and associated parts and components were contacted and discussions were undertaken concerning their fabrication of various components for marine application, utilizing a set of standardized component types and construction detail plans for guidance.

The manufacturers were selected from advertisements in trade journals, and from information given by regional SMACNA (Sheet Metal and Air Conditioning Contractors National Association Inc.) offices. The only criteria for selection was a reasonable proximity to sea coasts or the Great Lakes.

In order to provide a standardized format for review with proposed fabricators, the following items served as a basis for discussion:

- Standard Components Straight Duct Elbows Vaned Turns Transformations
- Transverse Connection Types Flanges
 Drive-Cleats
 S-Clips
 Riveting
- Longitudinal Seams Pittsburgh Snap-Lock Weld
- Duct Materials Steel, galvanized or otherwise suitably protected.
- Size limitations due to shop capacity.

- Tolerances required by standard plans.
- · Required lead time.
- Quote on prices for standard components.

Certain of the manufacturers expressed little interest in the concept primarily due to the gauge limitations of their shop's sheet metal forming machinery. Those interested and willing to manufacture the standardized duct and components are listed herein. Some have had previous experience with government contracts, and are therefore experienced in working within the limits established by specification requirements. In addition, the manufacturers listed have machinery capable of forming the 20 gauge and 16 gauge duct, and most have welding facilities for the heavier thicknesses.

Insofar as lead time is concerned, the fabricators indicated that this will depend on the size of the order, the number of different components required and the work loading existing in the various shops at the time or order. Most manufacturers were of the opinion that such work could be initiated in a timely fashion.

Concerning price quotations, it is generally their opinion that this would depend on the actual construction requirements (the actual request to bid on a particular contract), since the duct size variance is so great. Those manufacturers specializing in parts and components, such as transverse connections, vanes, vane runners, etc., would be able to price these items on a per-pound or per-foot basis, if they were provided with the necessary details.

All of the manufacturers listed stated that, given a copy of the design and construction standards, they would be willing to review these and comment in general regarding any thoughts they might have, and any simplification/changes they may recommend.

The following list comprises those contacted who expressed interest in the fabrication of duct and/or associated components for marine use. The listing constitutes approximately 50 percent of the companies contacted. It is emphasized that this is a very small sampling of the many sheet metal fabricators available and it is

₹3' believel that many of those not contacted would also be willing to fabricate the standard duct and components.

Company Name	Location	Telephone No
Advance Sheet Metal Company	Scattle, Washington	206/622-8390
Arco Heating and Air Conditioning Co.	Cleveland, Ohio	216/663-8915
Cain Manufacturing Inc.	Birmingham, Alabama	205/322-0353
Chambers Sheet Metal Company	Woodbury Heights. New Jersey	609/848-4774
Cleats Manufacturing Company	Chicago, Illin	312/521-0300
Hahnel Bros. Co.	Lewiston, Manie	207/784-6477
Holaday Parks Fabricators	Seattle, Washington	206/763-8500
Holzer Sheet Metal Company	New Orleans, Louisiana	504/525-8134
Juniper Industries, Inc.	New York, New York	212/326-2546
James A. Nelson Co.	San Francisco, Calif.	415/431-8202
Spears-Gutknecht Enterprises, Inc.	New Orleans, Louisiana	504/822-3182

